

Official

SEP 18 1989

Florida Power Corporation
Mr. W. S. Wilgus
Vice President, Nuclear Operations
ATTN: Manager, Nuclear Operations
Licensing
P. O. Box 219-NA-21
Crystal River, FL 32629

Gentlemen:

SUBJECT: ENFORCEMENT CONFERENCE
CRYSTAL RIVER DOCKET NO. 50-302

This letter confirms the telephone conversation between Mr. K. Wilson of your staff and Mr. R. Crlenjak of my staff on September 12, 1989, concerning an enforcement conference to be conducted at the Region II Office, 29th floor conference room on September 28, 1989, at 1:00 p.m. The purpose of this meeting is to discuss: 1) Vendor Branch inspection issues as delineated in our Report No. 50-302/89-200; 2) improper impeller installed on the Raw Water Pump as delineated in our Report No. 50-302/89-24; 3) station battery tested to improper load profile as delineated in our Report No. 50-302/89-24; 4) DC components subjected to improper voltages, as reported by your staff on September 7, 1989; and 5) improper voltage to AC motors, as reported by your staff on September 8, 1989.

Should you have any questions regarding these arrangements, we will be pleased to discuss them with you.

Sincerely,

Original signed by
Charles W. Hehl (for)

Stewart D. Ebnetter
Regional Administrator

cc: Gary L. Boldt
Vice President, Nuclear Production
Florida Power Corporation
P. O. Box 219-SA-2C
Crystal River, FL 32629

P. F. McKee, Director
Nuclear Plant Operations
Florida Power Corporation
P. O. Box 219-NA-2C
Crystal River, FL 32629

cc contd: (See page 2)

8910030564 890918
PDR ADDCK 05000302
G PNU

FEAS
110
EEOT

(cc cont'd)

R. C. Widell, Director
Nuclear Site Support
Florida Power Corporation
P. O. Box 219-NA-2J
Crystal River, FL 32629

A. H. Stephens
General Counsel
Florida Power Corporation
MAC - A5D
P. O. Box 14042
St. Petersburg, FL 33733

Attorney General
Department of Legal Affairs
The Capitol
Tallahassee, FL 32304

Jacob Daniel Nash
Office of Radiation Control
Department of Health and
Rehabilitative Services
1317 Winewood Boulevard
Tallahassee, FL 32399-0700

Administrator
Department of Environmental
Regulation
Power Plant Siting Section
State of Florida
2600 Blair Stone Road
Tallahassee, FL 32301

State Planning and Development
Clearinghouse
Office of Planning and Budgeting
Executive Office of the Governor
The Capitol Building
Tallahassee, FL 32301

Chairman
Board of County Commissioners
Citrus County
110 N. Apopka Avenue
Iverness, FL 36250

Robert B. Borsum
Babcock and Wilcox Company
Nuclear Power Generation Division
1700 Rockville Pike, Suite 525
Rockville, MD 20852-1631

State of Florida

bcc: Document Control Room

NRC Resident Inspector
U. S. Nuclear Regulatory Commission
15760 W. Power Line Street
Crystal River, FL 32629

*Concurrences

*RII: DRP
SVias
SVias
09/15/89

RII: DRP
RCr
RCr/enjak
09/15/89

RII: DRP
MS
MSinkule
09/15/89

RII: DRP
Reyes
Reyes
09/18/89

Jenkins
Jenkins
9/18/89

Reynolds
Reynolds
9/18/89