

TABLE 3.3.2-2 (Continued)

ISOLATION ACTUATION INSTRUMENTATION SETPOINTS

TRIP FUNCTION	TRIP SETPOINT	ALLOWABLE VALUE
1. PRIMARY CONTAINMENT ISOLATION		
a. Reactor Vessel Water Level -		
1. Low, Level 1	$\geq + 162.5$ inches (a)	$\geq + 162.5$ inches (a)
2. Low, Level 2	$\geq + 112$ inches (a)	$\geq + 112$ inches (a)
3. Low, Level 3	$\geq + 2.5$ inches (a)	$\geq + 2.5$ inches (a)
b. Drywell Pressure - High	≤ 2 psig	≤ 2 psig
c. Main Steam Line		
1. Radiation - High	$\leq 3 \times$ full power background	$\leq 3.5 \times$ full power background
2. Pressure - Low	≥ 825 psig	≥ 825 psig
3. Flow - High	$\leq 140\%$ of rated flow	$\leq 140\%$ of rated flow
d. Main Steam Line Tunnel Temperature - High	$\leq 200^\circ\text{F}$	$\leq 200^\circ\text{F}$
e. Condenser Vacuum - Low	≥ 7 inches Hg vacuum	≥ 7 inches Hg vacuum
f. Turbine Building Area Temp - High	$\leq 200^\circ\text{F}$	$\leq 200^\circ\text{F}$
g. Main Stack Radiation - High	(b)	(b)

TABLE 3.3.2-2

ISOLATION ACTUATION INSTRUMENTATION SETPOINTS

TRIP FUNCTION	TRIP SETPOINT	ALLOWABLE VALUE
1. PRIMARY CONTAINMENT ISOLATION		
a. Reactor Vessel Water Level -		
1. Low, Level 1	$\geq + 162.5$ inches (a)	$\geq + 162.5$ inches (a)
2. Low, Level 2	$\geq + 112$ inches (a)	$\geq + 112$ inches (a)
3. Low, Level 3	$\geq + 2.5$ inches (a)	$\geq + 2.5$ inches (a)
b. Drywell Pressure - High	≤ 2 psig	≤ 2 psig
c. Main Steam Line		
1. Radiation - High	≤ 3 x full power background	≤ 3.5 x full power background
2. Pressure - Low	≥ 825 psig	≥ 825 psig
3. Flow - High	$\leq 140\%$ of rated flow	$\leq 140\%$ of rated flow
4. Flow - High	$\leq 40\%$ of rated flow	$\leq 40\%$ of rated flow
d. Main Steam Line Tunnel Temperature - High	$\leq 200^\circ\text{F}$	$\leq 200^\circ\text{F}$
e. Condenser Vacuum - Low	≥ 7 inches Hg vacuum	≥ 7 inches Hg vacuum
f. Turbine Building Area Temp - High	$\leq 200^\circ\text{F}$	$\leq 200^\circ\text{F}$
g. Main Stack Radiation - High	(b)	(b)

DISTRIBUTION

~~Docket File~~

NRC PDR

Local PDR

S. Varga 14-E-4

G. Laines 14-H-3

E. Adensam 14-B-20

P. Anderson 14-B-20

T. Le 14-B-20

L. Spessard MNBB 3701

OGC 15-B-18

D. Hagan MNBB-3302

E. Jordan MNBB-3302

B. Grimes 9-A-2

T. Meek (4 cys for each Docket No.) P1-137

Wanda Jones P-130A

J. Calvo 11-F-23

ACRS (10) P-315

GPA/PA 17-F-2

ARM/LFMB AR-2015

BRUNSWICK FILE