

Rope Ferry Rd. (Route 156), Waterford, CT 06385

Millstone Nuclear Power Station Northeast Nuclear Energy Company P.O. Box 128 Waterford, CT 06385-0128 (860) 447-1791 Fax (860) 444-4277

The Northeast Utilities System

July 25, 1997

Docket No. 50-423 B16632

Re:10CFR 50.73(a)(2)(i)(B)

U. S. Nuclear Regulatory Commission Document Control Desk Washington, DC 20555

Millstone Nuclear Power Station Unit 3
Licensee Event Report 97-043-00
Submitted Pursuant to 10CFR 50.73(a)(2)(i)(B)

This letter forwards Licensee Event Report 97-043-00, documenting a condition that was determined reportable at Millstone Unit No. 3 on June 30, 1997. This LER is submitted pursuant to 10CFR 50.73(a)(2)(i)(B). NNECO's commitments in response to this event are contained within Attachment 1 to this letter.

Should you have any questions regarding this submittal, please contact Mr. David A. Smith at (860) 437-5840.

Very truly yours.

NORTHEAST NUCLEAR ENERGY COMPANY

190011

G. D. Hicks

Unit Director, Millstone Unit No. 3

I E22/

\*1 970725 K 05000423 PDR

V. \$2-95

tatun irm irm irmi m irm irm irm

U.S. Nuclear Regulatory Commission B16632/Page 2

Attachment: 1) NNECO's commitments in response to LER 97-043-00

2) LER 97-043-00

cc: H. J. Miller, Region I Administrator

A. C. Cerne, Senior Resident Inspector, Millstone Unit No. 3

J. W. Andersen, NRC Project Manager, Millstone Unit No. 3

W. D. Travers, Dr., Director, Special Projects

## Attachment 1

Millstone Nuclear Power Station, Unit No. 3
NNECO's Commitments
In Response To
(LER 97-043-00)

## Attachment 1 List of Regulatory Commitments

The following table identifies those actions committed to by NNECO in this document. Please notify the Manager - Nuclear Licensing at the Millstone Nuclear Power Station Unit No. 3 of any questions regarding this document or any associated regulatory commitments.

Number	Commitment	Due
B16632-01	The Channel Calibration and Analog Channel Operational Test procedures for Pressurizer Pressure P-11, Low-Low Tavg, P-12 and Turbine Impulse Chamber Pressure, P-13 will be revised to comply with the Technical Specifications.	Prior to entry into Mode 4.

## Attachment 2

Millstone Nuclear Power Station, Unit No. 3
NNECO's Submittal of
(LER 97-043-00)