

INDUSTRIAL PRETREATMENT
QUARTERLY SELF-MONITORING RESULTS

Perry Nuclear Power Plant
10 Center Rd.
Perry, Ohio 44081

Permit No.: 1004911
Report Date: 1/13/98
Laboratory: Electro Analytical

Date of Sample: 1/5 to 1/6/98
Sample Location: Sewage Pump Station


Time of sample: 1030
Name of Sampler: Beckler

Laboratory Address: 7118 Industrial Park Blvd.
Mentor, Ohio 44060-5314

Date of Analysis: 1/6 to 1/12/98
Flow: 33,000 gpd

PARAMETER	SAMPLE TYPE	EPA METHOD	ANALYSIS DATE	DISCHARGE LIMIT	ANALYSIS RESULT
COD	Composite	410.4	1/6/98	n/a	150 mg/l
BOD	Composite	405.1	1/12/98	n/a	50 mg/l
TSS	Composite	160.2	1/7/98	n/a	44 mg/l
Silver	Composite	272.1	1/9/98	n/a	<.050 mg/l
Mercury	Composite	245.1	1/12/98	2 ug/l	<.50 ug/l
pH	Composite	150.1	1/7/98	5.5 to 12 s.u.	8.4 s.u.
Oil/Grease	Grab	413.1	1/6/98	50 mg/l	18 mg/l

I certify under penalty of law that I have personally examined and I am familiar with the information in this report and that, based on my inquiry of those persons immediately responsible for obtaining the information contained in this report, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.


Signature

3/9/97
Date

Vice President - Nuclear
Title

9803230127 980312
PDR ADOCK 05000440
R PDR