

**TU**ELECTRIC

Log # TXX-98148  
File # 10200  
Ref. # 10CFR50.73 (voluntary)

June 8, 1998

**C. Lance Terry**  
Senior Vice President  
& Principal Nuclear Officer

U. S. Nuclear Regulatory Commission  
Attn.: Document Control Desk  
Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)  
DOCKET NOS. 50-445 AND 50-446  
VOLUNTARY LICENSEE EVENT REPORT (LER);  
LICENSEE EVENT REPORT 446/97-004-01

- REF: 1) Letter logged TXX-95006, dated January 23, 1995 from C. L. Terry to the NRC.
- 2) Letter logged TXX-97262, dated December 10, 1997 from C. L. Terry to the NRC.

Enclosed is supplement 1 of the voluntary Licensee Event Report (LER) 97-004 for Comanche Peak Steam Electric Station Unit (CPSES) 2, "Gaps in Structural Components of the Containment Sump Trash Racks." This supplement provides the results of follow-up commitments to review similar past work activities and inspect the Unit 1 Containment Sump Trash Racks.

Sincerely,

*C. L. Terry*  
C. L. Terry

JDS:jh  
Enclosure

cc: Mr. E. W. Merschhoff, Region IV  
Mr. J. I. Tapia, Region IV  
Resident Inspectors, CPSES

9306120036 980608  
PDR ADOCK 03000446  
S PDR

COMANCHE PEAK STEAM ELECTRIC STATION  
P.O. Box 1002 Glen Rose, Texas 76043-1002