

ENCLOSURE 3

VOGTLE ELECTRIC GENERATING PLANT - UNIT 1
MONTHLY OPERATING REPORT FOR APRIL 1998

TABLE OF CONTENTS

OPERATING DATA REPORT and CHALLENGES to PORV and SAFETY VALVES

Page E1-1

OPERATING DATA REPORT

Docket No.: 50-424
Unit Name: VEGP UNIT 1
Date: June 1, 1998
Completed By: T.S. Hargis
Telephone: (706) 826-3469

Operating Status

1. Reporting Period:	Apr-98		
2. Design Electrical Rating (Net MWe):	1169		
3. Maximum Dependable Capacity (Net MWe):	1162		
	This Month	Year To Date	Cumulative
4. Number Of Hours Reactor Was Critical:	719.0	2879.0	83,851.0
5. Hours Generator On Line:	719.0	2879.0	82,553.8
6. Unit Reserve Shutdown Hours:	0.0	0.0	0.0
7. Net Electrical Energy Generated (MWh):	843,811 *	3,398,891 *	90,861,203 *

*Revised

CHALLENGES TO PRESSURIZER PORV AND PRESSURIZER SAFETY VALVES

Date	Tag No.	Event Description
N/A	N/A	N/A