POR Odvance by Per I factor

## PRELIMINARY NOTIFICATION - NOT FOR PUBLIC DISCLOSURE

January 16, 1976

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE -- PNO-76-06

This preliminary notification constitutes EARLY astice of events of POSSIBLE safety or public interest significance. The information presented is as initially received without verification or evaluation and is basically all that is known by OIE staff as of 3:15 P.M. on date of this notification. IT SHOULD BE SPECIFICALLY NOTED THAT THIS NOTIFICATION MAY CONTAIN INFORMATION THAT LATER MAY BE DETERMINED TO BE INACCURATE OR INCONSISTENT. AN OFFICE OF INSPECTION AND ENFORCEMENT NOTIFICATION OF AN INCIDENT OR OCCURRENCE (BLUE SHEET) SUBSEQUENTLY WILL BE ISSUED IF WARRANTED.

Facility: Yankee Rowe (DN 50-029)

Subject: UNPLANNED OUTAGE

At 4:30 a.m. on January 13, 1976 a short developed in one of four reactor coclant pump motor stators and the reactor tripped from eighty percent power.

No spare pump is available at the facility. Also the current core is limited to four pump operation by Technical Specifications, since three pump operation was not analyzed in the core safety analysis.

Duration of the outage is expected to be either three or four weeks.

The licensee is proceeding with two plans to return to operation. The first plan involves borrowing a pump motor from Consolidated Company of New York (Indian Point 1). The motor is currently being removed from Indian Point 1. Removal, shipment and installation is expected to take three weeks.

The second plan involves obtaining authorization from NRR to operate with three pumps. A revised core safety analysis is currently being prepared. Preparation, submittal, and approval of this analysis are expected to take two weeks from date of shutdown. This plan will be adopted for plant operation if problems develop in utilizing the Indian Point 1 motor.

Media interest is expected because of the extended outage. The State of Massachusetts has been informed. A press release is being issued by the licensee.

Continued

9806190295 760116 PDR I&E PNO-76-006 PDR Region I, NRC, Philadelphia, Pa. received original notification of this occurrence from an NRC inspector on site at 10:40 a.m. January 13, 1976. The additional details including the extent of the outage and NRR's preliminary position, were developed subsequently. The information is up to date as of 1:00 p.m. January 16, 1976.

Contact: FADreher, IE x2	7261 GWRoy, IE x27353	JGDavis, IE x27541
Distribution:		
Chairman Anders	Commissioner Mason	S. J. Chilk, SECY
Commissioner Gilinsky	Commissioner Rowden	G. F. Murphy, JCAE
Commissioner Kennedy	C. C. Kammerer, CA	
L. V. Gossick, EDO		J. A. Harris, PA
B. C. Rusche, NRR	J. La Fleur, ISP	T. J. McTiernan, AIA
K. R. Chapman, NMSS	H. K. Shapar, ELD	
Transmitted: P. Bldg V00	H St U 20 . MARR M.	1