



Carolina Power & Light Company
P.O. Box 10429
Southport, NC 28461-0429

June 12, 1998

SERIAL: BSEP 98-0131

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 AND 2
DOCKET NOS. 50-325 AND 50-324/LICENSE NOS. DPR-71 AND DPR-62
CONVERSION TO IMPROVED TECHNICAL SPECIFICATIONS
CORRECTION TO LICENSE AMENDMENTS 203 AND 233
(NRC T.C NOS. M97243 AND M97244)

Gentlemen:

On June 5, 1998, the NRC issued Amendments 203 and 233 to the Technical Specifications for the Brunswick Steam Electric Plant (BSEP), Unit Nos. 1 and 2, respectively. These amendments approved the conversion from the current Technical Specifications to the Improved Technical Specifications (ITSs), as contained in Revision 1 of NUREG-1433, "Standard Technical Specifications General Electric Plants, BWR/4." This letter requests a correction to Amendments 203 and 233.

A discrepancy has been identified on page 3.3-56 for Unit 1 and Unit 2. Table 3.3.6.1-1, "Primary Containment Isolation Instrumentation," Function 4.c, "RCIC Steam Supply Line Pressure - Low," incorrectly requires the Allowable Value to be ≤ 53 psig. The correct Allowable Value is ≥ 53 psig. Replacement pages 3.3-56 for Units 1 and 2 are enclosed.

The erroneous inequality sign was inadvertently introduced in Carolina Power & Light (CP&L) Company's November 1, 1996, license amendment request (Serial: BSEP 96-0414) for conversion to the ITSs. Revision 1 of NUREG-1433, Table 3.3.6.1-1, Function 4.b, which is the basis for BSEP ITS Table 3.3.6.1-1, Function 4.c, incorrectly lists the Allowable Value of the RCIC Steam Supply Line Pressure - Low Function as $\leq [60]$ psig. CP&L properly incorporated the plant specific value of 53 psig for this function, but did not identify the erroneous inequality sign. The supporting documentation for the conversion to the ITSs does not request or describe changing the allowable value from ≥ 53 psig to ≤ 53 psig.

In order to support the planned implementation of the ITSs on July 11, 1998, CP&L requests that the corrected page 3.3-56 for Amendments 203 and 233 be issued by July 6, 1998.


9806220074 980612
PDR ADOCK 05000324
P PDR

A0011

Document Control Desk
BSEP 98-0131 / Page 2

There are no regulatory commitments contained in this submittal. Please refer any questions regarding this submittal to Mr. Warren J. Dorman, Supervisor - Licensing, at (910) 457-2068.

Sincerely,

A handwritten signature in dark ink, appearing to read "Keith R. Jury". The signature is fluid and cursive, with a prominent loop at the end.

Keith R. Jury
Manager - Regulatory Affairs
Brunswick Steam Electric Plant

MAT/mat

Enclosure:

Corrected Page 3.3-56 for Units 1 and 2

cc (with enclosure):

U. S. Nuclear Regulatory Commission, Region II
ATTN: Mr. Luis A. Reyes, Regional Administrator
Atlanta Federal Center
61 Forsyth Street, SW, Suite 23T85
Atlanta, GA 30303

U. S. Nuclear Regulatory Commission
ATTN: Mr. Charles A. Patterson, NRC Senior Resident Inspector
8470 River Road
Southport, NC 28461-8869

U. S. Nuclear Regulatory Commission
ATTN: Mr. David C. Trimble, Jr. (Mail Stop OWFN 14H22)
11555 Rockville Pike
Rockville, MD 20852-2738

Ms. Jo A. Sanford
Chair - North Carolina Utilities Commission
P.O. Box 29510
Raleigh, NC 27626-0510

Mr. Mel Fry
Director - Division of Radiation Protection
North Carolina Department of Environment and Natural Resources
3825 Barrett Drive
Raleigh, NC 27609-7221