

## ELECTRICAL POWER SYSTEMS

### A.C. SOURCES

### SHUTDOWN

### LIMITING CONDITION FOR OPERATION

---

- d. With the Fuel Storage System volume less than 75,000 gallons but greater than 65,600 gallons of fuel for the diesel generator, restore the Storage System fuel oil level to a minimum volume of 75,000 gallons within 48 hours or immediately declare the diesel generator inoperable and perform ACTION a.
- e. With the Fuel Storage System volume equal to 65,600 gallons or less, immediately declare the diesel generator inoperable and perform ACTION a.

### SURVEILLANCE REQUIREMENTS

---

4.8.1.2 The above required A.C. electrical power sources shall be demonstrated OPERABLE by the performance of each of the requirements of Specifications 4.8.1.1.1 and 4.8.1.1.2\* (except for Specification 4.8.1.1.2a.5).

---

\*The 18 month surveillance test interval is extended to 24 months for Train A, Unit 2, to remain in effect until the completion of the second refueling outage for Unit 2.

COMANCHE PEAK - UNITS 1 & 2

3/4 8-10a

Unit 1 - Amendment No. 43, 60

Unit 2 - Amendment No. 29, 46

9806220362 980615  
PDR ADOCK 05000445  
P PDR