



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

NORTH ATLANTIC ENERGY SERVICE CORPORATION, ET AL.\*

DOCKET NO. 50-443

SEABROOK STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 58  
License No. NPF-86

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment filed by the North Atlantic Energy Service Corporation, et al. (the licensee), dated March 2, 1998, as supplemented by letter dated April 21, 1998, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

\*North Atlantic Energy Service Corporation (NAESCO) is authorized to act as agent for the: North Atlantic Energy Corporation, Canal Electric Company, The Connecticut Light and Power Company, Great Bay Power Corporation, Hudson Light & Power Department, Massachusetts Municipal Wholesale Electric Company, Montaup Electric Company, New England Power Company, New Hampshire Electric Cooperative, Inc., Taunton Municipal Light Plant, The United Illuminating Company, and Vermont Electric Generation and Transmission Cooperative, Inc., and has exclusive responsibility and control over the physical construction, operation and maintenance of the facility.

9806300472 980624  
PDR ADDCK 05000443  
P PDR


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-86 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 58, and the Environmental Protection Plan contained in Appendix B are incorporated into Facility License No. NPF-86. NAESCO shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance, to be implemented within 60 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Cecil O. Thomas, Director  
Project Directorate I-3  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical  
Specification:

Date of Issuance: June 24, 1998

ATTACHMENT TO LICENSE AMENDMENT NO. 58

FACILITY OPERATING LICENSE NO. NPF-86

DOCKET NO. 50-443

Replace the following page of the Appendix A, Technical Specifications, with the attached page as indicated. The revised page is identified by amendment number and contains vertical lines indicating the area of change. An overleaf page has been provided.\*

Remove

3/4 5-5

3/4 5-6\*

Insert

3/4 5-5

3/4 5-6\*



## EMERGENCY CORE COOLING SYSTEMS

ECCS SUBSYSTEMS - T<sub>avg</sub> GREATER THAN OR EQUAL TO 350°F

### SURVEILLANCE REQUIREMENTS

4.5.2 Each ECCS subsystem shall be demonstrated OPERABLE:

- a. At least once per 24 hours by verifying that the following valves are in the indicated positions with power to the valve operators removed:

<u>Valve Number</u>	<u>Valve Function</u>	<u>Valve Position</u>
SI-V-3	Accumulator Isolation	Open*
SI-V-17	Accumulator Isolation	Open*
SI-V-32	Accumulator Isolation	Open*
SI-V-47	Accumulator Isolation	Open*
SI-V-114	SI Pump to Cold-Leg Isolation	Open
RH-V-14	RHR Pump to Cold-Leg Isolation	Open
RH-V-26	RHR Pump to Cold-Leg Isolation	Open
RH-V-32	RHR to Hot-Leg Isolation	Closed
RH-V-70	RHR to Hot-Leg Isolation	Closed
SI-V-77	SI to Hot-Leg Isolation	Closed
SI-V-102	SI to Hot-Leg Isolation	Closed

- b. At least once per 31 days by:

- 1) Verifying that the ECCS piping is full of water by venting the ECCS pump casings (excluding the operating centrifugal charging pump) and accessible discharge piping high points, and
- 2) Verifying that each valve (manual, power-operated, or automatic) in the flow path that is not locked, sealed, or otherwise secured in position, is in its correct position.

- c. By a visual inspection which verifies that no loose debris (rags, trash, clothing, etc.) is present in the containment which could be transported to the containment sump and cause restriction of the pump suctions during LOCA conditions. This visual inspection shall be performed:

- 1) For all accessible areas of the containment prior to establishing primary CONTAINMENT INTEGRITY, and
- 2) At least once daily of the areas affected within containment by containment entry and during the final entry when primary CONTAINMENT INTEGRITY is established.

\*Pressurizer pressure above 1000 psig.

## EMERGENCY CORE COOLING SYSTEMS

ECCS SUBSYSTEMS - T<sub>avg</sub> GREATER THAN OR EQUAL TO 350°F

### SURVEILLANCE REQUIREMENTS

---

#### 4.5.2 (Continued)

d. At least once per 18 months by:

- 1) Verifying automatic interlock action of the RHR system from the Reactor Coolant System to ensure that with a simulated or actual Reactor Coolant System pressure signal greater than or equal to 365 psig, the interlocks prevent the valves from being opened.
- 2) A visual inspection of the containment sump and verifying that the subsystem suction inlets are not restricted by debris and that the sump components (trash racks, screens, etc.) show no evidence of structural distress or abnormal corrosion.

e. At least once per 18 months, during shutdown, by:

- 1) Verifying that each automatic valve in the flow path actuates to its correct position on (Safety Injection actuation and Automatic Switchover to Containment Sump) test signals, and
- 2) Verifying that each of the following pumps start automatically upon receipt of a Safety Injection actuation test signal:
  - a) Centrifugal charging pump,
  - b) Safety Injection pump, and
  - c) RHR pump.

f. By verifying that each of the following pumps develops the indicated differential pressure on recirculation flow when tested pursuant to Specification 4.0.5:

- 1) Centrifugal charging pump,  $\geq 2480$  psid;
- 2) Safety Injection pump,  $\geq 1445$  psid; and
- 3) RHR pump,  $\geq 171$  psid.