

Dominion Energy Nuclear Connecticut, Inc.
5000 Dominion Boulevard, Glen Allen, VA 23060
DominionEnergy.com



September 10, 2020

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Serial No. 20-145A
NRA/SS R0
Docket No. 50-423
License No. NPF-49

DOMINION ENERGY NUCLEAR CONNECTICUT, INC.
MILLSTONE POWER STATION UNIT 3
ASME SECTION XI INSERVICE INSPECTION PROGRAM
SUPPLEMENT TO RELIEF REQUEST FOR LIMITED COVERAGE EXAMINATIONS
PERFORMED IN THE THIRD PERIOD OF THE THIRD 10-YEAR INSPECTION
INTERVAL

By letter dated June 17, 2020 (ADAMS Accession No. ML20169A512), Dominion Energy Nuclear Connecticut, Inc. (DENC) submitted relief requests for the limited coverage examinations performed in the third period of the third 10-year inservice inspection interval at Millstone Power Station Unit 3.

This supplement corrects an American Society of Mechanical Engineers (ASME) Code reference in Attachment 3 (Relief Request IR-3-42) of the June 17, 2020 submittal. Specifically, in Attachment 3 for Relief Request IR-3-42, DENC stated that Weld 03-073-008, an Examination Category C-A Pressure Retaining Weld in Pressure Vessels less than 2 inches in thickness, was examined using equipment and procedures written in accordance with ASME Section XI, Appendix I and Section V, Article 4. This code reference is incorrect since it applies to vessel welds greater than 2 inches in thickness. For vessel welds not greater than 2 inches in thickness, ASME Code, Section XI, Article I-2210 states that ultrasonic examination shall be conducted in accordance with Appendix III, as supplemented by Table I-2000-1. DENC's review of the examination records for Weld 03-073-008, confirmed that the weld was correctly examined in accordance with ASME Section XI, Appendix III, as supplemented by Table I-2000-1.

Should you have any questions regarding this submittal, please contact Shayan Sinha at (804) 273-4687.

Sincerely,

A handwritten signature in black ink, appearing to read "Mark D. Sartain", followed by a horizontal line.

Mark D. Sartain
Vice President – Nuclear Engineering & Fleet Support

Attachment: None

Commitments made in this letter: None

cc: U.S. Nuclear Regulatory Commission
Region I
2100 Renaissance Blvd, Suite 100
King of Prussia, PA 19406-2713

R. V. Guzman
Senior Project Manager - Millstone Power Station
U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Mail Stop O8 C2
Rockville, MD 20852-2738

NRC Senior Resident Inspector
Millstone Power Station