


DAMPER	SERVICE	CONTROL SWITCH	LOCATION	SEPARATION GROUP	POSITION SWITCH	COMPUTER POINT
HZ-85	DECON ROOM EXHAUST ISOLATION	HIS-85	068	1	ZS-85	Z-85
HZ-86	" " " "	HIS-86	"	4	ZS-86	Z-86
HZ-87	" " " "	HIS-87	"	1	ZS-87	Z-87
HZ-88	" " " "	HIS-88	"	4	ZS-88	Z-88

HZ-69	HOT MACHINE SHOP/HOT INST. SHOP ISO.	HIS-69	"	1	ZS-69	Z-69
HZ-70	" " " "	HIS-70	"	4	ZS-70	Z-70
HZ-71	" " " "	HIS-71	"	1	ZS-71	Z-71
HZ-72	" " " "	HIS-72	"	4	ZS-72	Z-72
HZ-73	NON-RADIOACTIVE TUNNEL ISOLATION	HIS-73	"	1	ZS-73	Z-73
HZ-74	" " " "	HIS-74	"	4	ZS-74	Z-74
HZ-75	RADIOACTIVE " " "	HIS-75	"	1	ZS-75	Z-75
HZ-76	" " " "	HIS-76	"	4	ZS-76	Z-76



- REFERENCES
M-02GLOZ(Q)
M-02GLO3(Q)
E-03GL14(Q)
E-03GL30(Q)

COORDINATION SIGN-OFF DOCUMENT ID: J-02GL13(Q)

REV	NO.	DATE	BY	CHK	ENGR	APP	APP
	1						
	2						
	3						
	4						
	5						
	6						
	7						
	8						

	BECHTEL GAITHERSBURG, MARYLAND SNUPPS JOB NO. 10466	CONTROL LOGIC DIAGRAM AUXILIARY BUILDING HVAC ISOLATION DAMPERS	UTILITY DWG. NO. REV. BECHTEL DWG. NO. REV. J-02GL13(Q) 3 DWG. APPLICABLE TO LIMITS REVIEW LEVEL 3	
	DESIGNED: <i>DQH</i> DRAWN: <i>CSB</i> DATE: 1-76	CHECKED: <i>[Signature]</i> ENGR: <i>[Signature]</i> APPR: <i>[Signature]</i>	DATE: 1-76	REV. 1: <i>[Signature]</i> REV. 2: <i>[Signature]</i> REV. 3: <i>[Signature]</i>
	NO. DATE 1 1-76 2 1-76 3 1-76	REVISIONS 1 REMOVE HZ 32, 33 SPR 2-GL-CN 2 ADD INTERLOCK 3 REVISED AS NOTED 4 ISSUED FOR CONSTRUCTION	DESIGNED: <i>DQH</i> DRAWN: <i>CSB</i> DATE: 1-76	REV. 1: <i>[Signature]</i> REV. 2: <i>[Signature]</i> REV. 3: <i>[Signature]</i>
	NO. DATE 1 1-76 2 1-76 3 1-76	REVISIONS 1 REMOVE HZ 32, 33 SPR 2-GL-CN 2 ADD INTERLOCK 3 REVISED AS NOTED 4 ISSUED FOR CONSTRUCTION	DESIGNED: <i>DQH</i> DRAWN: <i>CSB</i> DATE: 1-76	REV. 1: <i>[Signature]</i> REV. 2: <i>[Signature]</i> REV. 3: <i>[Signature]</i>

I certify that the image contained on this frame was made in the normal and regular course of business, on the date stated below and that it is an accurate reproduction of the document(s) submitted to Micrographics.
 DATE: 7-83 OPERATOR: *[Signature]* SUPERVISOR: *[Signature]*

16X

11 APERTURE CARD

PDR RIDS

8410030186

