



NOTES:

1. VALVES, SERVICE, AND OTHER INFORMATION IS GIVEN ON J-026S03 (Q)
2. FOUR ISOLATION SWITCHES ARE PROVIDED ON THE MAIN CONTROL BOARD FOR POWER LOCK-OUT. HIS-40 LOCKS OUT POWER TO HV-12, -13, -14, -30. HIS-41 LOCKS OUT POWER TO HV-3, -4, -5, -35. HIS-42 LOCKS OUT POWER TO HV-17 AND-18. HIS-43 LOCKS OUT POWER TO HV-8 AND-9.

This drawing and the design it covers is the property of the utilities which are participating in the SNUPPS Project. It is loaned to the licensee's operator for use in the construction, operation, maintenance, or repair of the licensed unit and it shall not be reproduced, copied, loaned, exhibited, or used outside the licensed unit and it shall remain the property of the utilities.

W
NON-ISO ISO
CONTROL SWITCH
HIS-40, 41, 42, 43
CUTLER-HAMMER E-30DY-11
MAINTAINED CONTACT

| | | | | | | | | |
|--------------------------------------|-------|-------|-------|-------|--------|------|-------|----|
| 1 | NR | NR | NR | NR | NR | NR | NR | NR |
| 1 | NA | NA | NA | NA | NA | NA | NA | NA |
| REV. | ELEC. | COND. | MECH. | CIVIL | PL. | PL. | ARCH. | |
| | | | | | LAYOUT | ENG. | | |
| COORDINATION SIGN-OFF | | | | | | | | |
| DOCUMENT IDENTIFICATION J-026S10 (Q) | | | | | | | | |

REFERENCES:

- J-026S03
- M-026S01

TI
APERTURE
CARD

| | | | | | | |
|--|--|--|---|--------------------------|------------------|-----------------|
| | BECHTEL GAITHERSBURG, MARYLAND | | CONTROL LOGIC DIAGRAM | | UTILITY DWG. NO. | REV. |
| | SNUPPS JOB NO. 10466 | | HYDROGEN ANALYZER AND PASS CONTAINMENT ISOLATION VALVES POWER LOCKOUT | | BECHTEL DWG. NO. | REV. |
| | | | | J-026S10 (Q) | | 1 |
| | | | | DRG. APPLICABLE TO UNITS | | 1 2 3 4 5 6 7 8 |
| | | | | REVIEW LEVEL 2 | | |

I certify that the image contained on this frame was made in the normal and regular course of business, on the date stated below and that it is an accurate reproduction of the document(s) submitted to Micrographics.
DATE 12-17-81 OPERATOR Kelly Bush SUPERVISOR [Signature]

16X

8410030607

PDR RIDS

