



SCALING RULES
E-O3N801

SIZE E

TI APERTURE CARD

10466-E-03A001
10466-E-03A002
10466-E-03A006
10466-E-03A001
10466-E-03A002
10466-E-03N012

- NOTES:**
- THE AREA ENCLOSED BY THE DOTTED LINE IS THE SAME AS THE AREA ENCLOSED BY THE DOTTED LINE ASSOCIATED WITH EACH RELAY EXCEPT FOR TEST SWITCH NO'S WHICH ARE THE LAST 3 DIGITS OF CUMBER NO. AND ARE NUMBERED IN SEQUENCE FOR EACH CUMBER.
 - DELETED
 - A CIRCUIT BREAKER IS PROVIDED IN THIS POSITION ON UNION ELECTRIC CO. TO SUPPLY CATEGORY 1 PUMP HOUSE LOADS. THIS POSITION IS AN EMPTY SPACE ON KANSAS GAS & ELECTRIC.
 - DELETED

NO.	DATE	REVISION	BY	CHKD.
1	10/24/75	DESIGNED	JM	JK
2				
3				
4				

BECHTEL
GAITHERSBURG, MARYLAND

SNUPPS

LOWER MEDIUM VOLTAGE SYSTEM
CLASS IIE 4.16 KV THREE LINE
METER AND RELAY DIAGRAM

DATE: 10/24/75

SCALE: AS SHOWN

PROJECT NO. 10466
DRAWING NO. E-O3N801/014

REVIEW LEVEL 1

NO.	DATE	REVISION	BY	CHKD.
1	10/24/75	DESIGNED	JM	JK
2				
3				
4				

THIS DRAWING IS THE PROPERTY OF BECHTEL CORPORATION. IT IS TO BE USED ONLY FOR THE PROJECT AND AT THE SITE SPECIFICALLY IDENTIFIED HEREON. IT IS NOT TO BE REPRODUCED, COPIED, OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF BECHTEL CORPORATION.

I certify that the work on this drawing was done in accordance with the standards of the profession and that I am a duly licensed professional engineer in the State of Maryland.

8410040033

PDR RIDS

