

TRANSMITTER	INDICATOR	SERVICE	REMARKS	DWG.
MU-PT-1573	MU-PI-1573	LET DOWN PRESSURE		2024
PP-PT-1546	PP-PI-1546	AIR RECEIVER (PP-T-1A) HEADER PRESSURE	RECORDER PEN-1 PP-UR-1698	2032
PP-PT-1549	PP-PI-1549	AIR RECEIVER (PP-T-1B) HEADER PRESSURE	RECORDER PEN-2 PP-UR-1698	2032
SS-PT-1677	SS-PI-1677	CONDENSER "C" SAMPLE TRANSFER PUMPS DISCH.	RE ANAL. PANEL 40	2032
SS-PT-1678	SS-PI-1678	CONDENSER "C" SAMPLE TRANSFER PUMPS DISCH.	RE ANAL. PANEL 40	2015
WDG-PT-1487	WDG-PI-1487	WASTE GAS DECAY TANKS (WDG-T-1A) PRESSURE	WDG T-1A	2028
WDG-PT-1494	WDG-PI-1494	WASTE GAS DECAY TANKS (WDG-T-1B) PRESSURE	WDG T-1B	2028
WDG-PT-1502	WDG-PI-1502	VENT HEADER VACUUM PRESSURE		2028
WDG-PT-3030	WDG-PI-3030	WASTE GAS COMPRESSOR DISCH. PRESSURE 1A		2028
WDG-PT-3051	WDG-PI-3051	WASTE GAS COMPRESSOR DISCH. PRESSURE 1B		2028
WDL-PT-1202	WDL-PI-1202	REACTOR COOLANT DRAIN TANK	WDL T-1A	2027
WDL-PT-1211	WDL-PI-1211	REACTOR COOLANT DRAIN PUMP DISCH.		2027
WDL-PT-1217	WDL-PI-1217	REACTOR COOLANT BLEED HOLD UP TANK 1A		2027
WDL-PT-1230	WDL-PI-1230	REACTOR COOLANT BLEED HOLD UP TANK 1B		2027
WDL-PT-1243	WDL-PI-1243	REACTOR COOLANT BLEED HOLD UP TANK 1C		2027
WDL-PT-1265	WDL-PI-1265	REACTOR COOLANT BLEED TRANSFER PUMP DISCH.		2027
WDL-PT-1303	WDL-PI-1303	EVAPORATOR COND. PUMP 1A DISCH. (WDL-P-1A)		2027
WDL-PT-1310	WDL-PI-1310	EVAPORATOR COND. PUMP 1B DISCH. (WDL-P-1B)		2027
WDL-PT-1333	WDL-PI-1333	MISC. WASTE TANK (WDL-T-2) COVER GAS PRESS.	WDL T-2A	2045
WDL-PT-1369	WDL-PI-1369	AUX BLDG. SUMP TANK (WDL-T-5) COVER GAS PRESS.		2045
WDL-PT-1605	WDL-PI-1605	AUX BLDG. SUMP TANK PUMPS WTR. DISCH.		2045
WDL-PT-1606	WDL-PI-1606	MISC. WASTE HOLD UP TANK PUMPS WTR. DISCH.		2045
WDL-PT-1607	WDL-PI-1607	FILTER WDL-F4B DISCHARGE		2045
WDL-PT-3145	WDL-PI-3145	RC DRAIN PUMP WDL-P-7 DISCHARGE		2027
WDL-PT-3148	WDL-PI-3148	WASTE TRANSFER PUMP WDL-P-5A DISCHARGE		2027
WDL-PT-3149	WDL-PI-3149	WASTE TRANSFER PUMP WDL-P-5B DISCHARGE		2027
WDL-PT-3243	WDL-PI-3243	FILTER WDL-F4A DISCHARGE		2045

TRANSMITTER	INDICATOR	SERVICE	REMARKS	DWG.
WDS-PT-1720	WDS-PI-1720-1	CONCENTRATED WASTE TANK PRESSURE	WDS PANEL 100	2039
WDS-PT-1720	WDS-PI-1720-2	CONCENTRATED WASTE TANK PRESSURE	WDS PANEL 100	2039
WDL-PT-3018	WDL-PI-3018	CONT. DRAIN PUMP 15A DISCH. PRESS.	WDL PANEL 100	2045
WDL-PT-3019	WDL-PI-3019	CONT. DRAIN PUMP 15A DISCH. PRESS.	WDL PANEL 100	2045

*PP SYSTEMS SHOWN
+ WDL TANKS SHOWN



APPROVED BY CLIENT

BURNS AND ROE, INC.			
ORADELL, N. J. HEMPSTEAD, N. Y. LOS ANGELES, CALIF.			
INSTRUMENTATION & CONTROL SCHEMATIC			
PRESSURE, INDICATION & DATA-LOGGER/COMPUTER			
JERSEY CENTRAL POWER & LIGHT CO.			
THREE MILE ISLAND STATION - UNIT 2			
DRAWN BY	SCALE	DATE	SCALE
W. O. 2555	5/16/72	5/19/69	NONE
APPROVED FOR CONSTRUCTION		W. O. 2555	
CHIEF NUCLEAR ENGINEER		Dwg. 3090	

ENG. DES.	ELEC. ENG.	MECH. ENG.	CIVIL ENG.	INST. ENG.	REV. NO.	REVISIONS	APP. BY	BY	CHKD.	APP.	DATE
					1	ADDED PP-PT-3215 7515 REV. WDL-PT-1202 DELETED WDS-PT-1526 1112 1119 81720					
					2						

7905220012

7905220012

7905220012

