

TERA APERTURE CARD

INFORMATION
THIS DOCUMENT IS
SUBJECT TO REVISION
WITHOUT NOTIFICATION
TO THE USER OF THIS
COPY

NOTES

1. ALL PIPING TO BE 1/2" IPS SCH 40S ST. 5L UNLESS OTHERWISE SPECIFIED.
2. INSTRUMENT ROOT CONNECTIONS ARE 1/2" NOM. DIA.
3. ALL INTERCONNECTING PIPING EXCEPT THAT SHOWN WITHIN THE INLET HEADER-WATER REMOVAL SKID, TO BE SUPPLIED BY B&R.
4. PRESSURE SWITCH TIED TO LEAK-OFF TAP ON COMPRESSOR HOUSING TO DETECT FAILURE OF PRIMARY BELLOWS.
5. ALL OTHER INLETS TO BE ISOLATED WHEN EITHER THE PRESSURIZER RELIEF TANK VENT OR THE HEAD DEGASSING DELAY TANK VENT OR THE VOLUME CONTROL TANK VENT DURING SHUTDOWN OPERATION ARE BEING FED.
6. FOR B&R SUPPLIED EQUIPMENT SEE B&R P # 10, I-F-5043.
7. PIPING, VALVES, AND COMPONENTS IDENTIFIED AS "SAFETY CLASS 1, 2, OR 3" ARE SEISMICALLY DESIGNED. CLASS 7, 8, OR "C" ITEMS ARE NON-SEISMICALLY DESIGNED.
8. 1" HYDRO VENTS AND CHAINS TO BE LOCATED ON FAB 150'S.
9. TUBING BETWEEN SKIDS IS 1/2" NOM. DIA. PKG. NO. 012 SUFF 102


10. QUICK DISCONNECT FITTING FOR DRAINAGE WITH HOSE.
11. CHECK VALVE TO BE FIELD INSTALLED IN VENDORS PIPING.
12. VENDOR SUPPLIED INSTRUMENT TO BE INSTALLED IN B&R PIPING.

NO.	DATE	DESCRIPTION	BY	CHKD.	APP'D.
1	11/28/80	REVISED AS NOTED			
2	1/22/81	REVISED AS NOTED			
3	1/22/81	REVISED AS NOTED			
4	1/22/81	INITIAL ISSUE			

Brown & Root, Inc.
Houston, Texas

SOUTH TEXAS PROJECT		CONTRACT NO.	SCALES
PIPING DIAGRAM		CR-0241	NONE
GASEOUS WASTE PROCESSING SYSTEM		DRAWING NO.	7R-31
SHEET NO 2 OF 2		DRAWING NO.	I-F-5055-D

BROWN & ROOT INC.
MICROFILM SERVICES



THURSDAY, MAR. 8 1980

INFORMATION PRELIMINARY REVIEW USE CONSTRUCTION

RIDS

8112040649

