



POOR ORIGINAL

P&ID APERTURE CARD

NOTES CONTINUED:
 B PROVIDE A PLUG VALVE WITH A CAP ON THE VENT & DRAIN CONNECTION OF EACH NON Q' COOLING COIL. VALVE NUMBER IS ASSIGNED AS THESE ARE TREATED AS INSTRUMENT FOOT VALVES.

UNCONTROLLED DOCUMENT
 FOR REFERENCE ONLY

- NOTES:
1. SEE DRAWINGS M-100 FOR LEGEND AND SYMBOLS.
 2. INSTALL MANUAL AIR VENT VALVES 1/2" O.D. MIN. ON ALL HIGH POINTS OF THE SYSTEM.
 3. INSTALL DRAIN CONNECTION WITH BALL VALVE ON ALL LOW POINTS OF THE SYSTEM.
 4. ANY ALARM POINT ON THE HVAC LOCAL PANEL IC175 IS TO BE TRANSMITTED TO CONTROL RM PANEL IC051 AS GROUPAL ARM (SEE DWG VC174).
 5. REFER VENDOR DWG B556-M-310-71 FOR REFRIGERATION MACHINE FLOW SCHEMATIC.
 6. ALL PUMPS REQUIRE FLAT FACE (FF) MATING FLANGES.
 7. PRESSURE GAUGES (0-30 PSIG RANGE) SHALL BE PROVIDED ON OUTPUT OF EACH PNEUMATIC CONTROLLING DEVICE (TC).

REV.	DATE	DESCRIPTION
1	8/15/55	ISSUED PER D.W. # 578-1346 AND REDESIGNED SPEC 2426, 2426-1, 2426-2, 2426-3, 2426-4.
2	8/15/55	FIELD ASSIGNED LAST VALVE NO.
3	8/15/55	LAST VALVE NUMBERS
4	8/15/55	REDESIGNED SPEC 2426, 2426-1, 2426-2, 2426-3, 2426-4.
5	8/15/55	REDESIGNED SPEC 2426, 2426-1, 2426-2, 2426-3, 2426-4.
6	8/15/55	REDESIGNED SPEC 2426, 2426-1, 2426-2, 2426-3, 2426-4.
7	8/15/55	REDESIGNED SPEC 2426, 2426-1, 2426-2, 2426-3, 2426-4.
8	8/15/55	REDESIGNED SPEC 2426, 2426-1, 2426-2, 2426-3, 2426-4.

PERKINSVILLE POWER & LIGHT COMPANY

CONDENSER UNIT COOLERS

CONDENSATE PUMP ROOM UNIT COOLERS

TO AND FROM MECH. VACUUM PUMP SEAL WATER COOLER

NOTES CONTINUED:
 8. CONNECT IN JBD DRAIN CONNECTION FROM THE MECH. VACUUM PUMP TO THE COOLING COIL IN THIS PUMP ROOM MAINTAINING A POSITIVE VALVE SEAL FOR BOTH DRAIN LINES.

9856	M-188	14
E-106293		

CONDENSATE PUMP ROOM UNIT COOLERS (SEE DETAIL #1)

RIDS

8305260088

