

**TERA APERTURE CARD**  
 INFORMATION  
 THIS DOCUMENT IS  
 SUBJECT TO REVISION  
 WITHOUT NOTIFICATION  
 TO THE USER OF THIS  
 COPY

- NOTES**
1. ORIENT 3-WAY VALVE SO IT FAILS WITH FLOW TO THE RECYCLE EVAP FEED DEM.
  2. LOCATE REAGENT TANK AND PIPING TO ALLOW FOR GRAVITY DRAIN INTO EVAPORATOR.
  3. ISOLATION REQ'D ON LINES COMING FROM RECYCLE EVAPORATOR PKGE. RIB-EVAP TO LOCK DISCONNECTS.
  4. THIS EQUIPMENT AND PIPING TO BE LOCATED IN AREA MAINTAINED AT LEAST 65% OR HEAT TRACED.
  5. THIS DRAWING SUPERSEDES DRAWING F-15012.
- REFERENCE 3:**
1. FOR PIPING & INSTRUMENT SYMBOLS SEE DRAWINGS O-F-0001 & O-F-0002.
  2. WESTINGHOUSE DWG. 1202E18 SUB J SHEET 2 OF 2.


**Brown & Root Inc.**  
 Engineers & Constructors  
 HOUSTON, TEXAS

**SOUTH TEXAS PROJECT**  
 BOHON RECYCLE SYSTEM  
 SHEET 2 OF 2

CONTRACT NO. CR-0241 NONE  
 DRAWING NO. 51R-8  
 T-5011-G

INFORMATION PRELIMINARY REVIEW USE CONSTRUCTION

**BROWN & ROOT INC.**  
 MICROFILM SERVICES  
 FRIDAY, MAY 19 1978



66  
68  
8.5  
11  
17

11  
11  
8  
8.5  
11  
17

RIDS

8112070096

