



TABLE A

115V D.C. AT SWGR. REF. DNG. E-030813	E-030813	E-030813
RELAY NO. 115V D.C. AT SWGR. REF. DNG. E-030813	E-030813	E-030813
BACKUP RELAY NO. 115V D.C. AT SWGR. REF. DNG. E-030813	E-030813	E-030813
LOAD SHED RELAY NO. 115V D.C. AT SWGR. REF. DNG. E-030813	E-030813	E-030813
CPA LOCATION - CPA	NF039C	NF039C
MIS. WIPERS	EPH45A	EPH45A
MIS. LOCATION - MCB	RL017	RL017
SWGR. NO. - SWGR	NB0102	NB0102
AR Y. AND LOC. CPB	DP53A	DP53A
MOTOR NO.	DP501A	DP501A
SCHEMES NO.	1EWS9A	1EWS9A

TABLE B

MCC NO. - MCC	ND0102	ND0102
SWGR NO. - SWGR	DP501A	DP501A
HEATER SCHEME NO.	1EWS9A	1EWS9A

TABLE C

COMPUTER DNG.	J-195015	J-195015
BECHTEL V.P. NO.	EN03	EN03
COMPUTER POINT	EN03	EN03
COMPUTER LOCATION - PC	RA-3X	RA-3X
SWGR. NO. - SWGR	NB0102	NB0102
COMPUTER SCHEME	1EWS9A	1EWS9A

TABLE D

AUX. REL. REF. DNG.	E-030813	E-030813
AUX. REL. NO. - AA	Q2T05E1	Q2T05E2
AUX. REL. NO. - AA	3XEN3	3XEN4
AUX. REL. NO. - AA	RP 032	RP 033
MIS. A. LOC. MCB	RL017	RL017
MIS. B. LOC. SWGR	NB0102	NB0203
LOAD SHED RELAY NO.	K1123	K4123
CPA LOC. SWGR	1F039C	1F039C
CPC LOC. SWGR	5B033C	4E032C
SCHEMES NO.	1EWS9A	1EWS9A

TY APERTURE CARD

8. CONTACT NUMBERS IN PARENTHESIS ARE APPLICABLE TO CALLAWAY UNIT.

7. CONTACT OPENS WHEN CSAS IS PRESENT.

6. CONTACT CLOSING ON LOAD SEQUENCE STEP NO. 3.

5. PULLING IN "N" LIGHT FOR LAMP TEST REVERSES CONTACT POSITIONS.

4. 1/2 WATT 230 WATTS, MANUFACTURER WESTINGHOUSE WIPAP ARROUND TYPE.

3. FOR LOC. NO. 8 BREAKER ELEVATING MECHANISM CKT. INTERNALS SEE G.E. DNG. BECHTEL V.P. NO. E-030813.

2. CONTACT CLOSING ON LOSS OF OFF-V.E. POWER TO CLASS 1C 410V BUSES. FOR DETAILS SEE BECHTEL V.P. NO. J-195015.

1. CONTACT CLOSING ON LOAD SEQUENCE STEP NO. 3 IF CSAS IS PRESENT. RELAY DETAIL SEE BECHTEL V.P. NO. J-195015.

NOTES:

NO.	DATE	REVISION	BY	CHKD.	APP'D.

BECHTEL
SCHEMATIC DIAGRAM
CONTINENT SPRAY PUMPS

10496 E-030813 (3) 11

8410050280

PDR RIDS

