



REFERENCE DWG'S
 1. I-P-5049 COMPOSITE PIPING
 REAC. CONTAIN. BLDG PENET.
 SLEEVE SCHEDULE

NOTES
 1) DISCONNECT MAIN STEAM HEADER OUTLET TO SAFETY RELIEF VALVE
 MUST HAVE MIN. 6" DOSE. TRANSMISSION PIPE FROM INJECTOR TO
 VALVE INLET MUST HAVE 6" MIN. DOSE WITH 1000# RF FLANGE PN
 CONNECTION TO VALVE.
 2) MAIN STEAM EXTENSION HEADERS FROM CONTAINMENT PENETRATIONS
 TO THE M.S.V'S ARE 31" NOM. O.D.

TERA
 APERTURE
 CARD
 INFORMATION
 THIS DOCUMENT IS
 SUBJECT TO REVISION
 WITHOUT NOTIFICATION
 TO THE USER OF THIS
 COPY

NO.	DATE	DESCRIPTION	BY	CHKD	APP'D	DATE	NO.	DATE	DESCRIPTION	BY	CHKD	APP'D	DATE
1	11/27/75	ISSUED AS NOTED	J.M.	J.M.	J.M.	11/27/75	1	11/27/75	ISSUED AS NOTED	J.M.	J.M.	J.M.	11/27/75
2	1/13/77	REVISED AS NOTED	J.M.	J.M.	J.M.	1/13/77	2	1/13/77	REVISED AS NOTED	J.M.	J.M.	J.M.	1/13/77
3	1/20/77	REVISED AS NOTED	J.M.	J.M.	J.M.	1/20/77	3	1/20/77	REVISED AS NOTED	J.M.	J.M.	J.M.	1/20/77
4	1/27/77	GENERAL REVISIONS	J.M.	J.M.	J.M.	1/27/77	4	1/27/77	GENERAL REVISIONS	J.M.	J.M.	J.M.	1/27/77
5	1/27/77	ISSUED FOR CONSENTS	J.M.	J.M.	J.M.	1/27/77	5	1/27/77	ISSUED FOR CONSENTS	J.M.	J.M.	J.M.	1/27/77
6	1/27/77	ISSUED FOR INFORMATION	J.M.	J.M.	J.M.	1/27/77	6	1/27/77	ISSUED FOR INFORMATION	J.M.	J.M.	J.M.	1/27/77
7	1/27/77	PROPOSED REVISION	J.M.	J.M.	J.M.	1/27/77	7	1/27/77	PROPOSED REVISION	J.M.	J.M.	J.M.	1/27/77

Brown & Root, Inc.
 Engineers, Constructors
 HOUSTON, TEXAS

SOUTH TEXAS PROJECT		PKG. NO. 101	SUFF. 1.4
PIPING DIAGRAM		CONTRACT NO.	SCALE
MAIN STEAM		CR-0241	NONE
SHEET 1 OF 3		DRAWING NO.	5S-10
		IF-0016-K	

BROWN & ROOT INC.
 MICROFILM SERVICES

MONDAY, JULY 31 1980



PRELIMINARY REVIEW USE CONSTRUCTION

RIDS

8112070214

