



TI APERTURE CARD

NOTES

- FOR SHEET ISSUE RECORD & SHEET INDEX SEE THIS DWG, SHEET 00.
- FOR SCHEMATIC DIAGRAM SEE THIS DWG, SHEET 01 OF DWG, EI-0030 SHEET 24 & SHEET 45.
- ALL WIRING & CABLING FOR THIS EQUIPMENT IS ASSOCIATED CLASS 'IE', TRAIN 'AA'.
- FIELD TO REMOVE JUMPERS ON TERMINAL BLOCK 'AK' TERMINALS 9 & 10.
- ALL WIRING & CABLING FOR THIS EQUIPMENT IS NON CLASS 'IE'.
- FOR ADDITIONAL NOTES & SYMBOLS SEE THIS DWG, SHEET 01.
- SHIELD IS TO BE GROUND AT MULTIPLEXER CABINET ONLY.
- FIELD TO REMOVE JUMPERS ON TERMINAL BLOCK 'AL' TERMINALS 14, 15 & 16.

SYMBOLS

- STP - INDICATES SHUTDOWN TRANSFER PANEL I-LV-15, TRAIN 'A'
- HSD - INDICATES HOT SHUTDOWN PANEL I-LV-01, TRAIN 'A'
- ICB-II - INDICATES CONTROL BOARD ON ECP-03-B-I
- [] - INDICATES WIRE PREFIX SAME AS BREAKER NUMBER [EA1]
- CABLE DESTINATION
[] CABLE NO.
[] DWG. REFERENCE

CLASS I
(NUCLEAR SAFETY-RELATED)
SAFETY CLASS I, SEVERE CATEGORY 1
SAFETY CLASS 2, CLASS II, CLASS III
SAFETY CLASS 3, ASSOCIATED CIRCUITS

TEXAS UTILITIES GENERATING CO.
C.P.S.E. (CLEVELAND, TEXAS)
69KV SWITCHGEAR EBJG IEA1 START-UP BREAKER IEA1-1 SWITCH DEVELOPMENT & CONNECTION DIAGRAM
DWG. NO. 2323-EI-0031 SHEET 2 OF 2

REV.	DWN.	CHKD.	APPROVED/DATE	REMARKS
CP-2	DRUL	SUB	1/10/52/15	THIS DRAWING IS REVISED TO INCORPORATE PCA # 71852 REV. 2.

THE FINAL GIBBS & HILL, INC. ISSUE OF DRAWING NO. 2323-EI-0031, SM. 21 IS REVISION NO. 12 DATE 7/29/53

Gibbs & Hill, Inc. 2323-EI-0031 SHEET NO. 02

THIS DOCUMENT IS AFFECTED BY DESIGN CHANGES

8410050375

PDR RIDS

8410050375

