



- NOTES
1. AN INDICATOR SHALL BE DISPLAYED ON THE LOCAL FIRE PANEL AND THROUGH THE PLANT COMPUTER.
 2. HEADER ISOLATION VALVES WILL BE PLACED ABOVE GROUND. PIPING WILL BE ROUTED UNDERGROUND UP TO AND AT THE ISOLATION VALVE.
 3. FOR DETAILS, SEE CONCRETE DRAWING (LATER).
 4. ALL INSTRUMENTS SHOWN ON THIS DIAGRAM ARE PREFIXED BY THE UNIT NUMBER 0 UNLESS OTHERWISE NOTED. SEE GENERAL NOTE 0 010-F-0002.

INFORMATION
THIS DOCUMENT IS SUBJECT TO REVISION WITHOUT NOTIFICATION TO THE USER OF THIS COPY

DESIGN REVIEW WAIVED

NO.	DATE	BY	CHKD BY	APP'D BY	DESCRIPTION
A	12/27/81	PROPOSED REVISION			
B					
C					
D					
E					
F					

Brown & Root, Inc.
Engineers - Constructors
HOUSTON, TEXAS

SOUTH TEXAS PROJECT		CONTRACT NO.	SCALE
PIPING DIAGRAM		CR-0241	NONE
FUEL OIL STORAGE AND TRANSFER SYSTEM (AUXILIARY FUEL OIL SUBSYSTEM)		DRAWING NO.	0-F-0011-F

PRELIMINARY REVIEW USE CONSTRUCTION

BROWN & ROOT INC.
MICROFILM SERVICES



MONDAY, AUG. 24 1981

RIDS

8112070259

