



JOB NO. 7-11518 DWG. NO. BD-18

- LEGEND**
- PANEL MOUNTING INSTR.
 - RACK MOUNTED INSTR.
 - FIELD MOUNTED INSTR.
 - WORK SHEET NO.
 - TEST POINT
 - TEST JACK & SWITCH
 - COMPUTER INPUT
 - SWITCH & IND. LIGHT
 - RESISTOR
 - FURNISHED BY VENDOR
 - 10-50 MA DC OR AS NOTED
 - 115 VAC OR CONTACT CLOSURE
 - CIRCUIT NO. AS NOTED

TERA APERTURE CARD

9 67N-16761
 ** 67N-16760
 ALL OTHER 67N-16758

7-11518 CD-11
 7-11518 CD-13
 7-11518 CD-14 (CONTROL)
 7-11518 CD-15

INSTRUMENT BLOCK DIAGRAM
 ROCHESTER GAS AND ELECTRIC CORP.
 ROBERT EMMET GUNN NUCLEAR POWER STATION
 STEAM GENERATOR LEVEL LOOP A
 REACTOR CONTROL SYSTEM
 WESTINGHOUSE ELECTRIC CORP. - ATOMIC DIV.
 PITTSBURGH, PA.

CUSTOMER ORDER NO. 54A-6980GD	FOXBORO FW
FOXBORO ORDER NO. 67N-11518	THE FOXBORO COMPANY
FOXBORO ORDER NO. 67N-16760	FOXBORO, MASSACHUSETTS, U.S.A.
DES. R.M. BENDEKSEN 12-2-67	JOB NO. 7-11518 DWG. NO. BD-18
DR. L. PANNANEN 12-2-67	SHEET 1 OF 1 REV. Δ
APP. R.M.B. 12-2-67	

REVISION	NAME	DATE	DESCRIPTION
AS BUILT	W.F.M.	FEB 13 1967	AS BUILT
REVISION 1	I.G.	12-2-67	CHANGE TMR LM-463 J TO 461 B REVISE FW DRAWING INTERLOCK CKT PER CUSTOMER SKETCH
REVISION 2	K.M.B.	3-27-68	MISC. CHANGES REVISED PER EWE APP
REVISION 3	K.M.B.	3-27-68	ADDED PC-462 & PC-463 MOV'D TO 462 B INTD PKG. ADDED RELAYS IN FIELD. ADDED IN TEST POINTS. DELETED PC-462 & PC-463. REVISED PER WHSE MKD PRINT DATED 1-17-68

R1A5

8112070303

