



INFORMATION
THIS DOCUMENT IS
SUBJECT TO REVISION
WITHOUT NOTIFICATION
TO THE USER OR THIS
COPY

ACCUMULATOR TANKS
LIQUID LEVELS AND PRESSURES

CONTROL GROUP	ACCUM. TANK	LEVEL CHAN.	PRESS. CHAN.
2	A	950	960
		951	961
4	B	952	962
		953	963
3	C	954	964
		955	965

R.W.S.T. LIQUID LEVELS

PROTECTION SET	CON. FEED. GROUP	CHAN. NO.	PAM	ACT. TRAIN
II	2	931	2	A
III	3	932	1	B
IV	4	933	—	C

TERA
APERTURE
CARD

ACCUMULATOR TANKS LIQUID
LEVELS AND PRESSURES/
REFUELING WATER
STORAGE TANK LEVEL
PROTECTION SETS II, III & IV

11
10
9
8
7
6
5
4
3
2
1

NOTES:
(SEE SH. 1 FOR GENERAL NOTES AND REFERENCES)
1. ONLY USED IN CHANNEL 931.
2. ONLY LI-931 AND 932 ARE PAM INDICATORS.
3. AC RELAY LY/933C USED TO INTERFACE WITH TRAIN C ACTUATION RELAY ENCLOSURE (NOT SHOWN).

DESIGNER	M. S. HARRIS	DATE	1-22-76
CHECKED			
APP'D.			
SCALE	8758076	SHEET	31
DO NOT SCALE			

8.5"

8.5"

36"

36"

17"

17"

Z125X1422CWR

R105

8112080070

