


This drawing and the design it covers is the property of the Utilities which are participating in the Snupps Project. It is loaned to the borrower on the understanding that it will not be reproduced, copied, loaned, exhibited, or used except in the limited way and for the purposes permitted by the express agreement that it will not be reproduced, copied, loaned, exhibited, or used except in the limited way and for the purposes permitted by the written consent given by the Snupps Utilities to the borrower.



CONTACT MADE END	POSITION	
	REMOTE	LOCAL
1	X	
3		X
6	X	
7		X
8	X	
11		X
15	X	
16		X

ELECTROSWITCH  
 CAT. NO. 20KD-254D-4001  
 MAINTAINED CONTACTS  
 PISTOL GRIP HANDLE  
 HANDSWITCH (TRANSFER SW)  
 HS 113

REFERENCE DWGS:  
 M-02FC02

- FIELD TO REMOVE RESISTORS @ PANEL FC219.
- BOP INSTRUMENT RACK WIRING SHOWN ON DWG (J110-624)
- THIS SIGNAL DRIVES THE INDICATOR FOR FCHIK313B @ RPI188.
- THIS SIGNAL DRIVES THE INDICATOR FOR FCHIK313A @ RLO05.
- SEE V.P. DWG. M-021-158 FOR SPEED CONTROL SCHEMATIC.
- GROUND SHIELDS @ RPI147A ONLY. DO NOT TERMINATE RPO53DA TO FC219 SHIELDS @ FC219.

NOTES:

TI  
 APERTURE  
 CARD

NO.	DATE	DESIGNED	BY	CHKD	APP'D	DRWN	BY	CHKD	APP'D
SCALE	DESIGNED	BY	CHKD	APP'D	DRWN	BY	CHKD	APP'D	
<b>BECHTEL</b>									
GAITHERSBURG, MARYLAND									
<b>SNUPPS</b>									
SCHEMATIC DIAGRAM AUX FEED WATER PUMP TURBINE SPEED CONTROL AND MONITORING									
					UTILITY DRAWING NO. REV				
					JOB NO. BECHTEL DRAWING NO. REV				
					10486 E-23FC24 (Q) 0				
DRAWINGS APPLICABLE TO UNITS									

BLOCK DIAGRAM  
 SCHEME NO. 2FC24A  
 REVIEW LEVEL 3  
 SUPERSEDES DWG E-03FC24 (Q)

I certify that the image contained on this frame was made in the normal and regular course of business, on the date stated below and that it is an accurate reproduction of the document(s) submitted to Micrographics.  
 DATE 3/20/84 OPERATOR *Mark Rowland*



8410050 466

PDR RIDS

