



1. FOR GENERAL INFORMATION SEE SHEET 1 OF THIS DRAWING.
 2. SEE ADMINISTRATIVE PROCEDURE 10.

REVISION	DESCRIPTION
1.	ISSUED FOR CONSTRUCTION
2.	ISSUED FOR CONSTRUCTION
3.	ISSUED FOR CONSTRUCTION

NO.	DESCRIPTION
1.	11440-PP-0001, B/L2
2.	11440-PP-0002, B/L2
3.	11440-PP-0003, B/L2

- REVISION NOTES**
- (A) PORTIONS OF THE VOLUME CONTROL SYSTEM THAT CONNECT TO THE REACTOR COOLANT SYSTEM FORM PART OF THE REACTOR CONTAINMENT BOUNDARY AND HAVE BEEN CLASSIFIED IN CLASS 2 IN ACCORDANCE WITH SRP 0.2.1.11.4.1.
 - (B) PORTIONS OF THE CHEMICAL AND VOLUME CONTROL SYSTEM ARE PART OF THE REACTOR CONTAINMENT BOUNDARY AND HAVE BEEN CLASSIFIED IN CLASS 2 IN ACCORDANCE WITH SRP 0.2.1.11.4.1.
 - (C) PORTIONS OF THE REP SEAL WATER INJECTION LINES CONNECTING TO THE CHEMICAL AND VOLUME CONTROL SYSTEM HAVE BEEN CLASSIFIED IN CLASS 2 IN ACCORDANCE WITH REGULATORY GUIDE 1.26, ARTICLE 3.4.1.
 - (D) THE SAFETY RELATED PORTION OF THE REACTOR COOLANT PUMP SEAL WATER HAS BEEN CLASSIFIED IN CLASS 2 IN ACCORDANCE WITH REGULATORY GUIDE 1.26, ARTICLE 3.4.1.

FOR ISI CLASSIFICATION BOUNDARY DRAWING LEGEND AND SYMBOLS, SEE 11440-PP-0001.
 CONTRACTION DRAWING HANGING REFER TO P. 10 OF 11. THE CONSTRUCTION CLASSIFICATION BOUNDARY DRAWING AND/OR CAN BE DETERMINED BY INSPECTING THE LEGEND FOR CHANGES.

CAUTION:
 THE INFORMATION ON THIS DRAWING IS FOR REFERENCE ONLY. THE INFORMATION IS NOT TO BE USED FOR CONSTRUCTION OR OPERATION. PLEASE CONSULT THE DESIGNER FOR THE LATEST REVISIONS. THE ACTUAL WORK SHALL BE CONTROLLED BY THE DESIGNER'S REVISIONS.

REVISION DESCRIPTION

1. THE LINE ORIGINATOR OF VALVE 1150A (P-1000) IS NOT PART OF A SAFETY FUNCTION AND HAS NOT BEEN CLASSIFIED.

VIRGINIA POWER
 NORTH CAROLINA POWER
 ENGINEERING AND CONSTRUCTION
 RICHMOND, VIRGINIA

ISI CLASSIFICATION BOUNDARY DRAWING
CHEMICAL & VOLUME CONTROL SYSTEM
SURRY POWER STATION UNIT 1
VIRGINIA POWER

PDR RIDS

8812010372

