



This drawing and the design it covers are the property of BECHTEL. They are hereby loaned out on the borrower's express agreement that they will not be reproduced, copied, loaned, exhibited, or used except in the limited way and for the limited purpose permitted by the order to the borrower.

SIZE E

Tennessee River

SITE PLAN
NOT TO SCALE

EXPLANATION

	CONCRETE		INFERRED CONTACT SAND LENS
	CLAY FILL		
	SAND FILL		
	SAND (SP, SW, SR, SP-SM)		
	SILTY SAND (SM)		
	CLAYEY SAND (SC)		
	SILTY CLAY (CL)		
	F.W. - FINE WATER LINE		
	S.W. - SERVICE WATER LINE		
	D.B. - DUCT BANK		
	P.B.D. - POND BLOW-DOWN LINE		
	C-62 - BORING NUMBER		
	635.5 - GROUND SURFACE ELEVATION		
	7.8'S - DISTANCE AND DIRECTION PROJECTED TO SECTION LINE		
	T.D. 23.0'		

NOTES

- FOR SECTION LOCATIONS SEE DWG GSK-SWP1.
- BORINGS D-25, D-24 AND C-62 WERE DRILLED PRIOR TO PLANT CONSTRUCTION.
- TILL - GENETICALLY SIMILAR POORLY SORTED SILTY SANDS, SAND SILTS, AND SILTY CLAYS, INCLUDES SOME SAND LENSES.
- LACUSTRINE - SORTED SANDS.

FOR INFORMATION ONLY

BECHTEL
ANA ARBOR, MICHIGAN

MIDLAND PLANT UNITS 1 & 2
CONSUMERS POWER COMPANY

GEOLOGICAL CROSS SECTIONS
B-B' AND C-C'
SERVICE WATER PUMP STRUCTURE

JOB NO.	DRAWING NO.	REV.
7220	GSK-SWP3	0

8306270246

INFORMATION COPY

POOR ORIGINAL
PRC
APERTURE
CARD

22"
17"
11"
8.5"
8.5"
11"
17"
22"

22"
17"
11"
8.5"
8.5"
11"
17"
22"

RIDS

8306270246

