

INFORMATION
THIS DOCUMENT IS
SUBJECT TO REVISION
WITHOUT NOTIFICATION
TO THE USER OF THIS
COPY
TERA
APERTURE
CARD

NOTES:

1) THIS LOGIC IS APPLICABLE TO THE FOLLOWING:

SERVICE	SOLENOID VALVE NO.	DAMPER NO.	ELECTRICAL REF. DIVG. NO.
NORM. CONT. PURGE INTAKE SUPP. DAMP.	FY-9686	FV-9686	1-B-7264
N.C. PURGE SUPP. FAN 11B DISCHG. DAMP.	FY-9691	FV-9691	1-B-7265
N.C. PURGE SUPP. FAN 11A DISCHG. DAMP.	FY-9693	FV-9693	1-B-7266
N.C. PURGE SUPP. FAN 11B DISCHG. DAMP.	FY-9701	FV-9701	1-B-7267
N.C. PURGE SUPP. FAN 11A DISCHG. DAMP.	FY-9703	FV-9703	1-B-7268

2) THIS DAMPER IS APPLICABLE TO SUPPLY TRAIN ONLY.

GENERAL NOTE:
THIS DRAWING REPRESENTS FUNCTIONAL REQUIREMENTS ONLY. REFER TO ELECTRICAL REFERENCE DRAWING FOR HARDWARE IMPLEMENTATION.

NO.	DATE	DESCRIPTION	BY	CHK	PROJ. ENGR.	PROJ. MGR.	DATE	DESCRIPTION	BY	CHK	PROJ. ENGR.	PROJ. MGR.
D 10/79		REVISED AS NOTED; ISSUED FOR USE										
C 11/77		ISSUED FOR USE										
B 11/77		EXTERNAL REVIEW; REVISED AS NOTED										
A 7/76		INITIAL REVIEW										

Brown & Root Inc.
 ENGINEERS-CONSTRUCTORS
 HOUSTON, TEXAS

SOUTH TEXAS PROJECT

DRAWING TITLE: RC.BLDG. HVAC NORMAL CONT. PURGE DAMPERS
 LOGIC DIAGRAM
 SYSTEM: V-14


CONTRACT NO. SCALE: CR-0241 N/A
 DRAWING NO. V-14: I-Z-3493D
 SHT. 3

PKG. NO. 132 AREA 102

PRELIMINARY REVIEW USE CONSTRUCTION

BROWN & ROOT INC. MICROFILM SERVICES

WEDNESDAY, OCT. 24 1979



RIDS

812090276

