



INFORMATION
THIS DOCUMENT IS
SUBJECT TO REVISION
WITHOUT NOTIFICATION
TO THE USER OF THIS
COPY

NOTES:
1. THIS LOGIC IS APPLICABLE TO THE FOLLOWING:

SERVICE	CONTROL ROOM ALARM LOCATION	TRAIN	ELECTRICAL REF. DWG. NO.
CONT. PEN. ISOL. VLV. CH-254 OVERLOAD	ZCP-001	A	1-E-7246
CONT. PEN. ISOL. VLV. CH-268 OVERLOAD	ZCP-001		1-E-7247
SUPPL. CONT. PURGE-CONT. PEN. ISOL. VLV. A OVERLOAD	ZCP-001		1-E-7274
SUPPL. CONT. PURGE-CONT. PEN. ISOL. VLV. D OVERLOAD	ZCP-001		1-E-7275
NORMAL CONT. PURGE-CONT. PEN. ISOL. VLV. A OVERLOAD	ZCP-001		1-E-7276
NORMAL CONT. PURGE-CONT. PEN. ISOL. VLV. C OVERLOAD	ZCP-001		1-E-7278
CONT. PEN. ISOL. VLV. CH-269 OVERLOAD	ZCP-002	B	1-E-7248
SUPPL. CONT. PURGE-CONT. PEN. ISOL. VLV. B OVERLOAD	ZCP-002		1-E-7270
SUPPL. CONT. PURGE-CONT. PEN. ISOL. VLV. E OVERLOAD	ZCP-002		1-E-7272
NORMAL CONT. PURGE-CONT. PEN. ISOL. VLV. B OVERLOAD	ZCP-002		1-E-7277
NORMAL CONT. PURGE-CONT. PEN. ISOL. VLV. D OVERLOAD	ZCP-002		1-E-7279
SUPPL. CONT. PURGE-CONT. PEN. ISOL. VLV. C OVERLOAD	ZCP-003		C
SUPPL. CONT. PURGE-CONT. PEN. ISOL. VLV. F OVERLOAD	ZCP-003	1-E-7273	

GENERAL NOTE:
THIS DRAWING REPRESENTS FUNCTIONAL REQUIREMENTS ONLY. REFER TO ELECTRICAL REFERENCE DRAWING FOR HARDWARE IMPLEMENTATION.

NO.	DATE	DESCRIPTION	BY	CHK	PROJ. ENGR.	PROJ. MGR.	DATE	DESCRIPTION	BY	CHK	PROJ. ENGR.	PROJ. MGR.	DATE
D 5/76		REVISED AS NOTED											
C 12/77		ISSUED FOR USE											
B 11/77		EXTERNAL REVIEW											
A 11/77		INTERNAL REVIEW											

BROWN & ROOT INC.
 ENGINEERS-CONSTRUCTORS
 HOUSTON, TEXAS

SOUTH TEXAS PROJECT

DRAWING TITLE: R.C. BLDG. HVAC CONT. PEN. ISOL. VALVES OVERLOAD LOGIC DIAGRAM SYSTEM: V-14
 CONTRACT NO. SCALE: CR-0241 N/A
 DRAWING NO. 4V-14
 1-Z-3491E SHT. 12
 PKG. NO. 132 AREA 102

PRELIMINARY REVIEW USE CONSTRUCTION

BROWN & ROOT INC.
 MICROFILM SERVICES



WEDNESDAY, OCT. 24 1979

RIDS

8112990286

