



INFORMATION
THIS DOCUMENT IS
SUBJECT TO REVISION
WITHOUT NOTIFICATION
TO THE USER OF THIS
COPY

NOTES:
1. THIS LOGIC IS APPLICABLE TO THE FOLLOWING:

SERVICE	CONTROL RM. SWITCH LOC.	MECHANICAL EQUIP. NO.	ELECTRICAL REF. DWG. NO.
CRDM VENT FAN IIA	ZCP-001	8-VI4-1-V-FN017	1-E-731C
CRDM VENT FAN IIB	ZCP-002	8-VI4-1-V-FN018	1-E-731I
CRDM VENT FAN IIC	ZCP-003	8-VI4-1-V-FN019	1-E-731J

2. PROVISIONS MUST BE PROVIDED TO SUPPLY POWER TO TWO FANS FROM DIESEL POWERED SAFETY BUSES WITHIN 30 MINUTES OF A STATION BLACKOUT AND/OR SAFETY INJECTION SIGNAL.

GENERAL NOTE:
THIS DRAWING REPRESENTS FUNCTIONAL REQUIREMENTS ONLY. REFER TO ELECTRICAL REFERENCE DRAWING FOR HARDWARE IMPLEMENTATION.

NO.	DATE	DESCRIPTION	BY	CHK	PROJ	ENG	MGR	DATE	DESCRIPTION	BY	CHK	PROJ	ENG	MGR
1	10/79	REVISED AS NOTED, ISSUED FOR USE												
2	12/77	ISSUED FOR USE												
3	4/77	EXTERNAL REVIEW; REVISIONS AS NOTED												
4	7/76	INITIAL REVIEW												

Brown & Root Inc.
ENGINEERS CONSTRUCTORS
HOUSTON, TEXAS

SOUTH TEXAS PROJECT

DRIVING TITLE
RC BLDG. HVAC
CRDM VENT FANS
LOGIC DIAGRAM
SYSTEM: V-14

CONTRACT NO. SCALE
CR-0241 N/A

DRIVING NO. DATE
1-2-3491 E
SHT. 7

PKG. NO. 132 AREA 102

PRELIMINARY REVIEW USE CONSTRUCTION



BROWN & ROOT INC.
MICROFILM SERVICES

THURSDAY, APR. 17 1980



TERA
APERTURE
CARD

