



GENERAL NOTE:
THIS DRAWING REPRESENTS FUNCTIONAL REQUIREMENTS ONLY. REFER TO ELECTRICAL REFERENCE DRAWING FOR HARDWARE IMPLEMENTATION.

NOTES:

- THIS LOGIC IS APPLICABLE TO THE FOLLOWINGS:
- LOCAL SWITCH IS TO BE LOCATED SO THAT THE FAN OPERATION MAY BE OBSERVED VISUALLY FROM THAT LOCATION.
- TRAIN B 1-Z-3601 SHT. 20 CO-ORD (G-9)
TRAIN C 1-Z-3602 SHT. 20 CO-ORD (G-9)
- TRAIN B 1-Z-3620 SHT. 6 CO-ORD (A-5)
TRAIN C 1-Z-3620 SHT. 6 CO-ORD (A-5)

SERVICE	CONTROL RM. SGL. LOCATION	LOCAL CONTROL	TRAIN	MECHANICAL EQUIP. NO.	ELECTRICAL REF. DWG. NO.
CLEAN-UP AIR UNIT IIA FAN	ZCP-001	LOCAL	A	3-VII-1-V-FN007	1-E-7413
CLEAN-UP AIR UNIT IIB FAN	ZCP-002	LOCAL	B	3-VII-1-V-FN008	1-E-7416
CLEAN-UP AIR UNIT IIC FAN	ZCP-003	LOCAL	C	3-VII-1-V-FN009	1-E-7417

DATE	DESCRIPTION	BY	CHK	ENG	PROJ	NO	DATE	DESCRIPTION	BY	CHK	ENG	PROJ	NO	DATE	DESCRIPTION
05/78	REVISED AS NOTED						05/77	ISSUED FOR USE							
07/77	ISSUED FOR USE						05/77	REVISED AS NOTED; ISSUED FOR USE							
03/77	EXTERNAL REVIEW; REVISED AS NOTED														
01/76	INITIAL REVIEW														

PKG. NO. 133 AREA 102

SOUTH TEXAS PROJECT

BROWN & ROOT INC.
ENGINEERS-CONSTRUCTORS
HOUSTON, TEXAS

DRAWING TITLE
ELEC. AUX. BLDG. & CONTROL ROOM CLEAN-UP AIR FANS LOGIC DIAGRAM SYSTEM-V-II

CONTRACT NO. SCALE
CR-0241 NA

DRAWING NO. SHEET NO.
1-Z-3460E SHT. 6

PRELIMINARY REVIEW USE CONSTRUCTION

BROWN & ROOT INC. MICROFILM SERVICES

INCHES
CM

RIDS

8117090557

