



INFORMATION  
THIS DOCUMENT IS  
SUBJECT TO REVISION  
WITHOUT NOTIFICATION  
TO THE USER OF THIS  
COPY

TERA  
APERTURE  
CARD

**NOTES:**

1. THIS LOGIC IS APPLICABLE TO THE FOLLOWINGS

SERVICE	CONTROL QM. SW. LOCATION	LOCAL CONTROL	TRAIN	MECHANICAL EQUIP. NO.	ELECTRICAL PER QM. NO.
HVAC RETURN AIR FAN 11A	ZCP-001	LOCAL	A	3-VII-1-V-FN001	1-E-7409
HVAC RETURN AIR FAN 11B	ZCP-002	LOCAL	B	3-VII-1-V-FN002	1-E-7410
HVAC RETURN AIR FAN 11C	ZCP-003	LOCAL	C	3-VII-1-V-FN003	1-E-7411

2. LOCAL SWITCH IS TO BE LOCATED SO THAT THE FAN OPERATION MAY BE OBSERVED VISUALLY FROM THAT LOCATION.

**GENERAL NOTE:**  
THIS DRAWING REPRESENTS FUNCTIONAL REQUIREMENTS ONLY. REFER TO ELECTRICAL REFERENCE DRAWING FOR HARDWARE IMPLEMENTATION.

DATE	DESCRIPTION	BY	CHK	PROJ. ENG.	PROJ. MGR.	D.V.	NO. DATE	DESCRIPTION	BY	CHK	PROJ. ENG.	PROJ. MGR.
08/77	REVISED AS NOTED, ISSUED FOR USE	RSV	WV	WV	WV	WV	2.0					
07/77	ISSUED FOR USE	WV	WV	WV	WV	WV	1.0					
06/77	EXTERNAL PERMIT REVISED AS NOTED	WV	WV	WV	WV	WV	1.0					
05/77	INITIAL REVIEWS	WV	WV	WV	WV	WV	1.0					

PKG. NO. 133 AREA 102

 <b>Brown &amp; Root Inc.</b> ENGINEERS-CONSTRUCTORS HOUSTON, TEXAS	<b>SOUTH TEXAS PROJECT</b>	DRAWING TITLE	CONTRACT NO. SCALE
		ELÉC. AUX. BLDG. & CONTROL ROOM RETURN AIR FANS	CR-0241 NA
		LOGIC DIAGRAM	DRAWING NO. 24-V-11
		SYSTEM: V-11	1-2-3460 D
			SHT. 5

PRELIMINARY  
 REVIEW  
 USE  
 CONSTRUCTION

**BROWN & ROOT INC.**  
MICROFILM SERVICES  
FRIDAY, OCT. 5



11  
8.5  
8.5  
11  
17

11  
8.5  
8.5  
11  
17



RIDS

8112090560

