

NOTE:
THIS LOGIC IS APPLICABLE TO THE FOLLOWING:

SERVICE	VALVE	REMOTE SWITCH LOCATION	ELECTRICAL REF. DIAG. NO.	ESF TRAIN	ESF MONITORING
ISOLATE STM.GEN.1B	AF-065	ZCP-002	1-E-6354	B	1-Z-3601 SHT.2
ISOLATE STM.GEN.1C	AF-085	ZCP-008	1-E-6355	C	1-Z-3602 SHT.2
ISOLATE STM.GEN.1D	AF-019	ZCP-001	1-E-6356	A	1-Z-3600 SHT.3
ISOLATE STAFF/TURR	MS-143	ZCP-001	1-E-6357	A	1-Z-3600 SHT.3
ISOLATE STM.GEN.1A	AF-043	ZCP-001	1-E-6353	A	1-Z-3600 SHT.2

2. ONE COMMON ANNUNCIATOR WINDOW FOR EACH TRAIN (A, B & C)

GENERAL NOTE:
THIS DRAWING REPRESENTS FUNCTIONAL REQUIREMENTS ONLY. REFER TO ELECTRICAL REFERENCE DRAWING FOR HARDWARE IMPLEMENTATION.

DATE	DESCRIPTION	BY	CHK	PROG	ENGR	MGR	DATE	DESCRIPTION	BY	CHK	PROG	ENGR	MGR
D 8/78	REV. AS NOTED - ISSUED FOR USE												
C 1/77	ISSUE FOR USE - REVISED AS NOTED												
B 2/77	REVISED AS NOTED & ISSUED FOR EXT. REVIEW												
A 2/76	INITIAL REVIEW												

PKG. NO. 095 AREA 102

Brown & Root Inc.
ENGINEERS-CONSTRUCTORS
HOUSTON, TEXAS


SOUTH TEXAS PROJECT

DRAWING TITLE: AUXILIARY FEEDWATER MOV LOGIC DIAGRAM
CONTRACT NO. SCALE: CR-0241 N/A
DRAWING NO. 4514
SYSTEM: S-14
SHEET: 5-3283F

INFORMATION PRELIMINARY REVIEW USE CONSTRUCTION

BROWN & ROOT INC.
MICROFILM SERVICES

FRIDAY, APR. 18 1980



INFORMATION
THIS DOCUMENT IS SUBJECT TO REVISION WITHOUT NOTIFICATION TO THE USER OF THIS COPY

TERA APERTURE CARD

MICROFILMED BY BROWN & ROOT INC. SEP 8 1979

RIDS

812090614

