



TERA APERTURE CARD

NOTES:  
THIS LOGIC IS APPLICABLE TO THE FOLLOWING:

	TRAIN A	TRAIN B	TRAIN C
RHR TRAINS	A	B	C
CCW PUMP DISCH. PRESSURE	PSL-4511	PSL-4516	PSL-4521
CCW PUMP FLOW	FSHL-4512	FSHL-4517	FSHL-4522
ALARM LOCATION	ZCP-001	ZCP-002	ZCP-003

INFORMATION  
THIS DOCUMENT IS SUBJECT TO REVISION WITHOUT NOTIFICATION TO THE USER OF THIS COPY

GENERAL NOTE:  
THIS DRAWING REPRESENTS FUNCTIONAL REQUIREMENTS ONLY. REFER TO ELECTRICAL REFERENCE DRAWING FOR HARDWARE IMPLEMENTATION.

DATE	DESCRIPTION	BY	CHK	PROJ	ENG	MGR	DATE	DESCRIPTION	BY	CHK	PROJ	ENG	MGR
10/17/77	ISSUED FOR USE / REV. AS NOTED	PS	PS	PS	PS	PS	10/17/77	ISSUED FOR USE / REV. AS NOTED	PS	PS	PS	PS	PS
10/17/77	REVISED AS NOTED	PS	PS	PS	PS	PS							
10/17/77	INITIAL REVIEW	PS	PS	PS	PS	PS							

Brown & Root Inc.  
ENGINEERS CONSTRUCTORS  
HOUSTON, TEXAS

SOUTH TEXAS PROJECT

DRAWING TITLE	CONTRACT NO. SCALE
CCW BYPASS STATUS	CR-0241 N/A
INOPERATIVE	
LOGIC DIAGRAM	DRAWING NO. CR-20
SYSTEM: R-20	1-Z-3183E
	SHT. 3
	PRELIMINARY [ ] REVIEW [ ] USE [ ] CONSTRUCTION

BROWN & ROOT INC.  
MICROFILM SERVICES

FRIDAY, NOV. 16 1979



RIDS

8112100128

