



TERA APERTURE CARD

NOTE:
1. THIS LOGIC IS APPLICABLE TO THE FOLLOWING:

	TRAIN A	TRAIN B	TRAIN C
CCW COMMON HEADER PRESS. LOW	PSL-4644	PSL-4644A	PSL-4644B
STANDBY START TRAIN A PRESS. SWITCH	PSL-6880A	PSL-6885A	PSL-6890A
STANDBY START TRAIN B PRESS. SWITCH	PSL-6880B	PSL-6885B	PSL-6890B
ALARM LOCATION	ZCP-001	ZCP-002	ZCP-003
CONTROL ROOM SWITCH LOCATION	ZCP-001	ZCP-002	ZCP-003

2. SWITCH IS FOR SELECTION OF ONE CCW PUMP AND ONE ESSENTIAL COOLING WATER PUMP. ANY TWO OF THE THREE TRAIN MODE SELECT SWITCHES IN "OFF" WILL ACTUATE THE CONTROL ROOM ANNUNCIATOR SYSTEM.

GENERAL NOTE:
THIS DRAWING REPRESENTS FUNCTIONAL REQUIREMENTS ONLY. REFER TO ELECTRICAL REFERENCE DRAWING FOR HARDWARE IMPLEMENTATION.

INFORMATION
THIS DOCUMENT IS SUBJECT TO REVISION WITHOUT NOTIFICATION TO THE USER OF THIS COPY

DW79 ISSUED FOR USE, REV. AS NOTED	BY: [Signature]	DATE: [Date]	DESCRIPTION: [Description]	BY: [Signature]	DATE: [Date]	DESCRIPTION: [Description]	BY: [Signature]	DATE: [Date]	DESCRIPTION: [Description]	BY: [Signature]	DATE: [Date]	DESCRIPTION: [Description]	BY: [Signature]	DATE: [Date]	DESCRIPTION: [Description]	BY: [Signature]	DATE: [Date]	DESCRIPTION: [Description]	BY: [Signature]	DATE: [Date]	DESCRIPTION: [Description]	
C777 REVISED AS NOTED																						
P276 NO REVISIONS																						
A276 INITIAL REVIEW																						

Brown & Root Inc.
ENGINEERS CONSTRUCTORS
HOUSTON, TEXAS

SOUTH TEXAS PROJECT

DRAWING TITLE
CCW ECW AUTO
TRAIN START
LOGIC DIAGRAM
SYSTEM: R-20

CONTRACT NO. SCALE
CR-0241 N/A

DRAWING NO. 88-20
1-Z-3183D
SHT. 1

PKG. NO. 097 AREA 102

PRELIMINARY REVIEW USE CONSTRUCTION

BROWN & ROOT INC.
MICROFILM SERVICES



FRIDAY, NOV. 13 1979

RIDS

817100134

