



- NOTES:-**
- FOR INTERNAL WIRING AND WIRE DIAGRAM, REFER TO DRAWING EC-210-787.
 - INTERNAL WIRING SHALL BE STRANDED COPPER BENTONITE WIRE 600V TYPE SIS 9044W.7 STRONG ROCKETTES PARALLEL INSULATED WITH NEAT DISTANCE & PLANE REGISTRY CROSSBUNDLED (SEE DRAWING).
 - INTERNAL WIRING TO TERMINAL BOARDS TB-2, TB-3 & TB-4 TO BE GREEN ACCORDING TO ALL EXISTING WIRING SHALL BE COLORED GREEN WITH GRAY WIRE NUMBER TYPE IN GOS OR 80070 TO INDICATE G & W CONNECTION.
 - INTERNAL WIRING TO TERMINAL BOARDS TB-1 & TB-5 TO BE GRAY ACCORDING TO INDICATE NON-RE WIRING.
 - FOR WIRING DETAILS SEE DRAWING EC-210-785 (CONNECTIONS - TERMINAL BOARDS - INTERNAL).
- FO-10000-000 CONSTRUCTION DETAILS

FLORIDA POWER CORPORATION
ST. PETERSBURG, FLORIDA
UNIT NO. 3
855,000 KW

ELECTRICAL
EPIC AUXILIARY CABINET B
TERMINAL BOARDS

APPROVED FOR CONSTRUCTION BY
FLORIDA POWER CORPORATION

REVISIONS

NO.	REVISIONS	DATE
1	AS BUILT PER MARK 77-247H-20-2-3-0, 20-2-3-4, 20-10-05-10, 21-2-20-4	
2	REVISED PER DCN 20-258	
3	REVISED PER DCN 20-277	
4	AS BUILT PER MARK 77-247H-20-2-3-0, 20-2-3-4, 20-10-05-10, 21-2-20-4	

FLORIDA POWER CORPORATION
ST. PETERSBURG, FLORIDA
UNIT NO. 3
855,000 KW

ELECTRICAL
EPIC AUXILIARY CABINET B
TERMINAL BOARDS

APPROVED FOR CONSTRUCTION BY
FLORIDA POWER CORPORATION

REVISIONS

NO.	REVISIONS	DATE
1	AS BUILT PER MARK 77-247H-20-2-3-0, 20-2-3-4, 20-10-05-10, 21-2-20-4	
2	REVISED PER DCN 20-258	
3	REVISED PER DCN 20-277	
4	AS BUILT PER MARK 77-247H-20-2-3-0, 20-2-3-4, 20-10-05-10, 21-2-20-4	

8902090147

PDR RIDS

