

ELEMENTARY DIAGRAM

REFERENCE DRAWINGS

- 0-6-0105 ELECT. WIRING STANDARDS & SYMBOLS.
- 1-2-3403 SH. 2 ELECT. AUX. BLDG. & CONT. RM. RETURN FAN UNITS RELIEF LINE DMPRS. LOGIC DIAG.
- 7244B71-1 SOLID STATE PROTECTION SYSTEM INTERCONNECTION DIAGRAM

INFORMATION
THIS DOCUMENT IS SUBJECT TO REVISION WITHOUT NOTIFICATION TO THE USER OF THIS COPY

LEGEND

- K823 - RELAY FOR SAFETY INJECTION & EMERG. BORATION. CONTACT OPENS ON S1/E8 SIGNAL.
- 20/FY-9338 - RETURN FAN UNIT IIA RELIEF LINE SOLENOID VALVE.
- 14R-002 - ACTUATION TRAIN A CABINET.
- 45RM-A - RADIATION MONITOR TRAIN A RELAY. CONTACT CLOSURES BELOW SETPOINT.
- - TERMINATION CABINET.

NUCLEAR SAFETY RELATED CLASS I/E		
PKG: 056A	SUFF: 102	ACT: 581
DRAWING TITLE ELECTRICAL CONTROL WIRING DIAGRAM		CONTRACT NO SCALE CR-0241 NONE
EAB HVAC CONT. RM. RETURN FAN UNIT IIA RELIEF LINE DMPR.		DRAWING NO 4-V-II 1E-7394-O


ISSUED FOR CONSTRUCTION	DATE	DESCRIPTION	BY	CHK	PROJ. ENG.	PROJ. MGR.	NO. DATE	DESCRIPTION	BY	CHK	PROJ. ENG.	PROJ. MGR.
ISSUED FOR CONSTRUCTION	1/21/73											

Brown & Root Inc.
ENGINEERS-CONSTRUCTORS
HOUSTON, TEXAS

SOUTH TEXAS PROJECT

INFORMATION PRELIMINARY REVIEW USE CONSTRUCTION

BROWN & ROOT INC.
MICROFILM SERVICES



MONDAY, JAN. 21 1973

RIDS

8112100223

