

TERA
APERTURE
CARD

REFERENCE DRAWINGS:
 0-E-0103 - ELECT. WIRING STANDARDS & SYMBOLS
 1-E-7457 - CONTROL WIRING DIAGRAM FUEL HDLG. BLDG. HVAC RAD. MONITORING SYSTEM

INFORMATION
 THIS DOCUMENT IS SUBJECT TO REVISION WITHOUT NOTIFICATION TO THE USER OF THIS COPY

LEGEND:
 RITS-8035 - RADIATION MONITOR A CONTACTS OPEN WHEN RAD. LEVEL IS ABOVE SETPOINT
 RITS-8036 - RADIATION MONITOR B CONTACTS OPEN WHEN RAD. LEVEL IS ABOVE SETPOINT
 45RMS-A - TRAIN-A RADIATION MONITOR CONTROL RELAY
 45RMS-B - TRAIN-B RADIATION MONITOR CONTROL RELAY
 45RMS-C - TRAIN-C RADIATION MONITOR CONTROL RELAY
 □ TERMINATION CAB.

HOLD

NUCLEAR SAFETY RELATED		
CLASS 1E		
PKG. : 01B	SUFF. : 101	ACT. : 581
DRAWING TITLE: ELECTRICAL	CONTRACT NO. CR-0241	SCALE NONE
ELEMENTARY DIAGRAM	DRAWING NO. 45V-12	
FUEL HDLG. BLDG. HVAC		
RAD. MONITORING SYST.		1-E-5457-B


NO.	DATE	DESCRIPTION	BY	CHK	PROJ. ENGR.	PROJ. MGR.	DEPT.	NO.	DATE	DESCRIPTION	BY	CHK	PROJ. ENGR.	PROJ. MGR.	DEPT.	NO.
B		ISSUED FOR USE	TY													
A		ISSUED FOR REVIEW	TY													

Brown & Root Inc.
 ENGINEERS CONSTRUCTORS
 HOUSTON, TEXAS

SOUTH TEXAS PROJECT

□ INFORMATION □ PRELIMINARY □ REVIEW □ USE □ CONSTRUCTION

BROWN & ROOT INC.
 MICROFILM SERVICES



FRIDAY, JULY 29 1977

REPRODUCED FROM MICROFILMED 44-2075

8.5"

11"

17"

RIDS

8112100239

