



NOTES:

1. RESETS FOLLOWING RESTORATION OF BUS POWER.
2. A DUMMY CB INPUT GENERATED ON THE LOGIC CARD SHALL BE PROVIDED TO THE MOTOR MD TO PREVENT A FALSE ALARM.
3. A DUMMY SC INPUT GENERATED ON THE LOGIC CARD SHALL BE PROVIDED TO THE CB MD TO PREVENT A FALSE ALARM.

4. POWER TO THIS OUTPUT DRIVER CONTACTS IS SUPPLIED BY WIRE NO. P3.

NO.	DATE	REVISIONS	BY	CHKD	DESIGN	ENGR	INSP	APPR
1	11/12	DESIGNED AS NOTED	LK					
2	11/12	DESIGN FREEZE ISSUE						
3	11/12	DESIGNED AS NOTED						
4	11/12	ENCL. DWT-1 AND REVISED RA INSCRIPTION						
5	11/12	REVISED AS NOTED						
6	11/12	REVISED AS NOTED						
7	11/12	ISSUED FOR CONSTRUCTION						

BECHTEL
SAN FRANCISCO

PUBLIC SERVICE ELECTRIC AND GAS COMPANY
HOPE CREEK GENERATING STATION

LOGIC DIAGRAM
AUXILIARY BLDG CONTROL AREA
CONTROL EQUIPMENT ROOM SUPPLY SYSTEM (CERS)

JOB No.	DRAWING No.	REV.
10855	H-89-0 SHT 3	5 Q



I certify that the microfilm image contained on this microform was made in the normal and regular course of business. This is a true, full, correct and complete reproduction and replacement for and/or in lieu of original documents generated by the Bechtel group of companies.

Signed: **DANNY** Date: **11/12** Camera Type: **MRC 1**
Camera Operator

RIDS

8307250212

