

13 0 42 } ESF MONITORING  
14 0 b } CAB IRR-032

21 0 } CONT. PWR. NOT } BYPASS STATUS } HOLD  
22 0 } 27 AVAILABLE OR MTR. } INOP. }  
 } OL'S TRIPPED. } I-E (LATER)

REFERENCE DRAWINGS

- 0-E-0105 ELECTRICAL WIRING STDS. & SYMBOLS
- 1-E-3470 FUEL HDLG. BLDG. HVAC
- 54.4 HHSI, LHSI & CS PUMPS SUPPL. CLR.
- FANS LOGIC DIAGRAM
- 1-E-7433 CONTROL WIRING DIAGRAM FUEL HDLG. BLDG.
- HVAC, LHSI, PP SUPPL. CLR. FAN IIA

INFORMATION  
THIS DOCUMENT IS  
SUBJECT TO REVISION  
WITHOUT NOTIFICATION  
TO THE USER OF THIS  
COPY

LEGEND

27 - LOSS OF CONTROL PWR RELAY  
IRR-032 - ESF MONITORING ACTUATION TRAIN A CAB.

TERA  
APERTURE  
CARD

CS-MB (1S190)

BLOCK	CONTACT	POSITION		USE
		STOP	AUTO START	
A	NC (1)	X		SP
	NO (2)		X	CONT
B	NC (3)		X	CONT
	NO (4)	X	X	SP



MAINTAINED CONTACTS  
X DENOTES CONTACTS CLOSED  
GE CAT # CR2940UB203C

MECH EQUIP NO 3V121VAH 004  
420V-MCC-EIA2-COMPT.N3

NUCLEAR SAFETY RELATED CLASS I E		
PKG: 011	SUFF: 101	ACT: 581
DRAWING TITLE ELECTRICAL ELEMENTARY DIAGRAM	CONTRACT NO CR-0241	SCALE NONE
FUEL HDLG. BLDG. HVAC LHSI, PP SUPPL. CLR. FAN IIA	DRAWING NO 4-V-12	1-E-5433-B

DATE	DESCRIPTION	BY	CHK	ENG	PROJ	ENGR	PROJ	ENGR	DATE	DESCRIPTION	BY	CHK	ENG	PROJ	ENGR
B/1/2	ISSUED FOR USE	T.D.													
A/1/2	ISSUED FOR REVIEW	T.Y.													


Brown & Root Inc.  
ENGINEERS-CONSTRUCTORS  
HOUSTON, TEXAS

SOUTH TEXAS  
PROJECT

INFORMATION PRELIMINARY REVIEW USE CONSTRUCTION

BROWN & ROOT INC.  
MICROFILM SERVICES

FRIDAY, JULY 6 1973



MICROFILMED SEP 21 1978

RIDS

8112100277

