

CS-MB (15154)

BLOCK	CONTACT	POSITION			CS-MB USE
		STOP	AUTO	START	
A	NC (1)		X	X	CONT.
	NO (2)	X			(CONT.)
B	NC (3)	X	X		SP
	NO (4)			X	CONT.

LCS-17409

BLOCK	CONTACT	POSITION			CS-MB USE
		STOP	AUTO	START	
A	NC (1)		X	X	CONT.
	NO (2)	X			SP
B	NC (3)	X	X		SP
	NO (4)			X	CONT.

- REFERENCE DRAWINGS**
- 0-E-0105 ELECTRICAL WIRING STANDARDS AND SYMBOLS
 - 1-Z-3460 ELECT. AUX. BLDG. & CONTROL ROOM RETURN AIR FANS LOGIC DIAGRAMS
 - 1-E-7409 CONTROL WIRING DIAGRAM ELECT. AUX. BLDG. HVAC RETURN AIR FAN IIA

LEGEND

27 - LOSS OF CONTROL POWER RELAY

TERA APERTURE CARD

INFORMATION
THIS DOCUMENT IS SUBJECT TO REVISION WITHOUT NOTIFICATION
MECH. EQUIP. NO. 3V111VFN001 USER OF THIS
480V-MCC-E1A1-COMPT. L3 COPY

NUCLEAR SAFETY RELATED CLASS I E

PKG : 042A | SUFF : 102 | ACT : 581


DRAWING TITLE	CONTRACT NO. SCALE
ELECTRICAL	CR-0241 NONE
ELEMENTARY DIAGRAM	DRAWING NO. 4.V-11
ELECT. AUX. BLDG. HVAC RETURN AIR FAN IIA	1-E-5409-C

DATE	DESCRIPTION	BY	CHK	PROJ. ENG.	PROJ. MGR.	DATE	DESCRIPTION	BY	CHK	PROJ. ENG.	PROJ. MGR.	DATE
	REVISED AS NOTED ISSUED FOR USE											
	REVISED AS NOTED & ISSUED FOR USE											
	ISSUED FOR REVIEW & COMMENT											


Brown & Root Inc.
ENGINEERS-CONSTRUCTORS
HOUSTON, TEXAS

SOUTH TEXAS PROJECT

INFORMATION PRELIMINARY REVIEW USE CONSTRUCTION



BROWN & ROOT INC.
MICROFILM SERVICES



RIPS

8112100316

