

CS-MB (15156)

CONTACT ON HANDLE END	POSITION			USE
	START	AUTO	STOP	
1 IC 2 ZC OHO OHO			X	CONT
2	X			CONT
3 3C 4 4C OHO OHO	X	X	X	SP
4	X	X		EP
5 5C 6 6C OHO OHO			X	CONT
6	X			SP

LCS 17406

CONTACT ON HANDLE END	POSITION			USE
	START	AUTO	STOP	
1 IC 2 ZC OHO OHO			X	CONT
2	X			CONT
3 3C 4 4C OHO OHO	X	X	X	SP
4	X			SP

- REFERENCE DRAWINGS:**
- 0-E-0105 - ELECT WIRING STANDARDS & SYMBOLS
  - 1-E-7406 - CONTROL WIRING DIAGRAM E.A.B. HVAC SH. 2 SUPPLY AIR FAN IIA
  - 1-Z-3460 - E.A.B. & CONTROL RM. SUPPLY AIR FANS SH. 3 LOGIC DIAGRAM
  - 7244D71 - SOLID STATE PROTECTION SYSTEM INTERCONNECTION DIAGRAM

- LEGEND:**
- ☐ - 480V - LC-EIA - COMPT. 3B
  - ⊠ - LOCATED AT MOTOR
  - IRR-002 - ACTUATION TRAIN A CAB
  - 45 RMA - CONTROL RM. RAD. MONITOR AUX. RELAY CONT. OPEN WHEN RAD. IS BELOW SETPOINT
  - K-823 - SAFETY INJECTION AUX. RELAY CONTACT CLOSING ON SI SIGNAL
  - 27 - LOSS OF CONTROL PWR RELAY.

**INFORMATION**  
THIS DOCUMENT IS SUBJECT TO REVISION WITHOUT NOTIFICATION TO THE USER OF THIS COPY

MECH. EQUIP. N2 3V111VAH001

**NUCLEAR SAFETY RELATED CLASS I E**

PKG: 042A SUFF: 102 ACT: 581


DRAWING TITLE: ELECTRICAL  
ELEMENTARY DIAGRAM  
ELECT AUX BLDG HVAC SUPPLY AIR FAN IIA

CONTRACT NO: CR-0241  
SCALE: NONE  
DRAWING NO: 4-V-II  
1-E-5406-C

NO	DATE	DESCRIPTION	BY	CHK	PROJ	PROJ	NO	DATE	DESCRIPTION	BY	CHK	PROJ	PROJ
C 1/4		REVISED AS NOTED ISSUED FOR USE											
B 1/4		REDRAWN ISSUED FOR USE											
A 1/4		ISSUED FOR REVIEW & COMMENT											


**Brown & Root Inc.**  
ENGINEERS CONSTRUCTORS  
HOUSTON, TEXAS

**SOUTH TEXAS PROJECT**



**BROWN & ROOT INC.**  
MICROFILM SERVICES

TUESDAY, JAN. 22 1980



INFORMATION PRELIMINARY REVIEW USE CONSTRUCTION

RIDS

812100318

