

42 TO ECW PUMP BLDG INTAKE DAMPER I-E-737B, SH 1

CS-MB (1S1G1)

BLOCK	CONTACT	POSITION		USE
		STOP	AUTO START	
A	NC(1)	X		SP
	NO(2)		X	CONT
B	NC(3)		X	CONT
	NO(4)	X		SP



LCS-17373

BLOCK	CONTACT	POSITION		USE
		REMOTE START	STOP	
A	NC(1)	X		SP
	NO(2)		X	CONT
B	NC(3)		X	SP
	NO(4)	X		SP



POOR ORIGINAL

- REFERENCE DRAWINGS
- 0-E-0105-ELECTRICAL WIRING STANDARDS & SYMBOLS
 - 1-Z-3510-SH1-ECW PUMP BLDG HVAC VENT FANS, LOGIC DIAGRAMS
 - 1-Z-3511-SH1-ECW PUMP BLDG HVAC VENT FANS INTAKE & OUTLET DREPPERS LOGIC DIAGRAMS
 - 1-E-7373 - CONTROL WIRING DIAGRAM ECW PUMP BLDG. HVAC VENT FAN 12A.
 - 1-E-4945 - ELEM. DIAGRAM ECW PUMP 1A

TERA APERTURE CARD

- LEGEND
- 20/FY9898- ECW PUMP BLDG VENT FAN 12A OUTLET DAMPER SOLENOID VALVE (FAILS OPEN)
 - 42X- LOW VOLTAGE PICK-UP RELAY
 - 480V-MCC-E1A3-COMPT. C2
 - TISH 9885-1-ECW PUMP BLDG. HVAC VENT FAN TEMP COILT. CONTACT CLOSURE ON HI-TEMP. (ISOLATED)
 - 27- LOSS OF CONTROL POWER RELAY.

INFORMATION
THIS DOCUMENT IS SUBJECT TO REVISION WITHOUT NOTIFICATION TO THE USER OF THIS COPY

MECH. EQUIP. NO 3V151VFN002


NUCLEAR SAFETY RELATED		
CLASS 1E		
PKG:007	SUFF:051	ACT 581
DRAWING TITLE	CONTRACT NO SCALE	
ELECTRICAL	CR-0241 NONE	
ELEMENTARY DIAGRAM	DRAWING NO 4-V-15	
ECW PUMP BLDG. HVAC C	1-E-5373-C	
VENTILATION FAN 12A		

DATE	DESCRIPTION	BY	CHK	PROJ	ENG	APP	DATE	DESCRIPTION	BY	CHK	PROJ	ENG	APP	DATE
	ISSUED FOR USE													
	REVIEWED & REVISION FOR COMMENT													
	ISSUE FOR REVIEW & COMMENTS													

Brown & Root Inc.
ENGINEERS CONSTRUCTORS
HOUSTON, TEXAS

SOUTH TEXAS PROJECT

BROWN & ROOT INC. MICROFILM SERVICES



17"

17"

RIPS

8112100225

