

ELEMENTARY DIAGRAM

- LEGEND
- 43QPP OIL PRE-POST LUBE PUMP MOTOR CONTROL SWITCH
  - 24/14RX2 RUNNING DETECTION REPEATER RELAY
  - 27 LOSS OF CONTROL POWER

INFORMATION  
THIS DOCUMENT IS  
SUBJECT TO REVISION  
WITHOUT NOTIFICATION  
TO THE USER OF THIS  
COPY

- REF. DWGS
- 0-E-0105 - ELECT. WIRING STANDARD & SYMBOLS
  - 1-E-1225 - ONE LINE DIAGRAM 480V ESF MCC-EIAI UNIT NO.1
  - GS-553-137 ENGINE CONTROL PANEL DG#11 SH. 24 OF 16

CS ZLP-102 43QPP

CONTACTS (HANDLE END)	POSITION			USE
	HAND	OFF	AUTO	
1C-1-02	X			CONT
30-1-09			X	CONT
5C-1-06	X			SP
70-1-08			X	SP

X DENOTES CONTACT CLOSED MAINTAINED CONTACTS (VENDOR FURNISHED)

STDBY DIESEL NO. II LUBE OIL CIRC. PUMP



TERA APERTURE CARD

480V MCC-EIAI COMPT. N2 ELECT. EQUIP. NO. 3E171EMCEIAI

NUCLEAR SAFETY RELATED CLASS IE

PKG: 014 SUFF: 105 ACT: 581

DRAWING TITLE: ELECTRICAL CONTROL WIRING DIAGRAM

CONTRACT NO. SCALE: CR-0241 NONE

DRAWING NO. 5-Q-15

I-E-7170-A


NO.	ISSUED FOR USE	DATE	DESCRIPTION	BY	CHK	PROJ. ENGR.	PROJ. MGR.	DATE	DESCRIPTION	BY	CHK	PROJ. ENGR.	PROJ. MGR.
A 1/2	ISSUED FOR USE			FM									

**Brown & Root Inc.**  
ENGINEERS-CONSTRUCTORS  
HOUSTON, TEXAS

**SOUTH TEXAS PROJECT**

INFORMATION PRELIMINARY REVIEW USE CONSTRUCTION

**BROWN & ROOT INC. MICROFILM SERVICES**



THURSDAY, MAY 17, 1979

MICROFILMED #1779

8.5"

11"

17"

RIDS

812100408

