

TERA APERTURE CARD

INFORMATION
THIS DOCUMENT IS SUBJECT TO REVISION WITHOUT NOTIFICATION TO THE USER OF THIS COPY

ESF MONITORING STATUS LB-2M25 WINDOW-37 CHILLED WATER OUTLET CONTMT. ISOL VALVE NOT FULL CLOSED.

CONTROL PHR. NOT AVAILABLE

BY PASS STATUS INOR LB-2M25 WINDOW 16 CHILLED WATER OUTLET CONTMT. ISOL. VALVE CH269

ANN. EQUIP CP-002 WINDOW (2-10) CONTMT ISOL. TRAIN B VLV OVERLOAD

CS-MB (2541)		CTMT PEN. ISOL. VALVE CH269	
BLOCK	CONTACT	POSITION	USE
A	NC (1)	X	SP
	NO (2)		SP
B	NC (3)	X	CONT
	NO (4)	X	CONT

SPRING RETURN TO AUTO
N- DENOTES CONTACTS CLOSED
GE CAT #CR2940US203A

CONTACT	VALVE POSITION		USE
	CLOSE	OPEN	
1			THIS DWG.
2			SP
3			THIS DWG.
4			THIS DWG.
5			THIS DWG.
6			SP
7			THIS DWG.
8			THIS DWG.
9			SP
10			SP
11			SP
12			SP
13			SP
14			SP
15			THIS DWG.
16			SP
17	OPENS ON MECH. OVERLOAD ON CLOSING		THIS DWG.
18	OPENS ON MECH. OVERLOAD ON OPENING		THIS DWG.

- REFERENCE DRAWINGS
- O-E-0105 - ELECTRICAL WIRING STANDARDS & SYMBOLS
 - I-2-3491 SH.10 - R.C. BLDG HVAC CTMT. PEN. ISOL. VALVES LOGIC DIAGRAM
 - I-E-7248 - CONTROL WIRING DIAGRAM R.C. BLDG HVAC CTMT. PEN. ISOL. VALVE CH269
 - I-2-3491 SH.12 - R.C. BLDG HVAC CTMT. PEN. ISOL. VLV'S OVERLOAD LOGIC DIAGRAM.

LEGEND:

- K836 - CONTAINMENT PHASE B ISOL. RELAY
- IRR-033 - TRAIN B ESF MONITORING CAB.
- 49X - MOTOR THERMAL OVERLOAD RELAY
- 27 - LOSS OF CONTROL PHR. RELAY.
- IRR00455P3 - ACTUATION TRAIN B CAB.

MECH. EQUIP N#2V14ITCH269
480V-MCC-EIB2-COMPT-C3

NUCLEAR SAFETY RELATED

CLASS I/E

PKG: 019	SUFF: 100	ACT: 581
DRAWING TITLE ELECTRICAL		CONTRACT NO SCALE CR-0241 NONE
ELEMENTARY DIAGRAM		DRAWING NO 4-V-1A
R.C. BLDG HVAC CTMT. PEN. ISOLATION VALVE CH269		I-E-5248-B


DATE	DESCRIPTION	BY	CHK	ENG	MC	DATE	DESCRIPTION	BY	CHK	ENG	MC
8/23	ISSUED FOR USE	VI									
8/23	ISSUE FOR REVIEW & COMMENT	T.P.									

Brown & Root Inc.
ENGINEERS CONSTRUCTORS
HOUSTON, TEXAS

SOUTH TEXAS PROJECT

REVISIONS: 1, 2, 3, 4, 5, 6, 7, 8, 9, 10

BROWN & ROOT INC.
MICROFILM SERVICES



8.5"
11"
17"

8.5"
11"
17"

RIDS

8112100494

