

INFORMATION
THIS DOCUMENT IS
SUBJECT TO REVISION
WITHOUT NOTIFICATION
TO THE USER OF THIS
COPY

TO ANN. COOL
WINDOW 6-2
"ECW PUMP IA
DISCHARGE
STRAINER TRIPPED"

TO ANN. COOL
WINDOW 5-2
"ECW PUMP IA
DISCHARGE
STRAINER HI DP"

BLOCK	CONTACT	POSITION			USE
		STOP	AUTO	START	
A	NC (1)	X			SP
A	NO (2)		X	X	CONT.
B	NC (3)			X	CONT.
B	NO (4)	X	X		SP

MAINTAINED CONTACT
X-DENOTES CONTACT CLOSED
G.E. CAT # CR2940UB203C

- REFERENCE DRAWINGS
- 0-E-0105 - ELECT. WIRING STANDARDS & SYMBOLS
 - I-Z-3202-SH.4 - ESSENTIAL COOLING WATER STRAINER LOGIC DIAGRAM
 - I-E-6961 - CONTROL WIRING DIAGRAM ESSENTIAL COOLING WATER STRAINER IA

NOTE
1. THIS RELAY IS LOCATED IN SEPARATE COMPT.

- LEGEND
- 63/PDIS-6859 - ECW STRAINER IA DIFFERENTIAL PRESS. CONTACT CLOSING ON HI DIFF. PRESS.
 - 27 - CONTROL PAIR, NOT AVAILABLE

480V MCC BIAS COMPT. A4
MECH. EQUIP. NO. 3R23INSFDIA


NUCLEAR SAFETY RELATED CLASS 1E		
PKG: 004	SUFF: 052	ACT: 581
DRAWING TITLE ELECTRICAL		CONTRACT NO. SCALE CR-0241 NONE
ELEMENTARY DIAGRAM		DRAWING NO. 4-R-28
ESSENTIAL COOLING WATER STRAINER IA		I-E-4961-B

NO.	DATE	DESCRIPTION	BY	CHK	ENG	PROJ	MGR
1		ISSUED FOR USE	OB				
2		ISSUED FOR REVIEW & COMMENT	A.S.				

Brown & Root Inc.
ENGINEERS CONSTRUCTORS
HOUSTON, TEXAS


**SOUTH TEXAS
PROJECT**

INFORMATION PRELIMINARY REVIEW USE CONSTRUCTION



BROWN & ROOT INC.
MICROFILM SERVICES

TUESDAY, NOV. 6 1979



8.5"

11"

17"

8.5"

11"

17"

RIDS

8112100515

