



SYSTEM FA

NO.	REFERENCE DRAWINGS	SHEET	DATE
1	AUXILIARY BOILERS CONTROL SCHEMATIC	M-11-4	05/25/53
2	MAIN DRUMS ELEMENTARY PIPING DIAGRAM	M-11-5	05/25/53
3	LOGIC DIAGRAM	J-10	
4	LOGIC DIAGRAM	J-21	

- NOTES:
1. THIS DRAWING SHOWS ALL OF THE MAJOR COMBUSTION CHIMNEY SYSTEM AND SUPERVISORY INSTRUMENT COMPONENTS LOCATED AT THE BOILERS OR THE CONTROL PANELS. ADDITIONAL DETAILS OF COMPONENT INTERCONNECTION ARE INCLUDED IN THE BOILER CONTROLS DRAWING LISTED AS REF. 1.
 2. DELETED
 3. THIS DRAWING SHOWS ONLY FIELD MOUNTED BURNER CONTROL SYSTEM DETAILS. COMPLETE DETAILS OF COMPONENT INTERCONNECTION ARE SHOWN ON THE CONTROL SYSTEM PIPING DIAGRAM LISTED AS REF. 2.
 4. ALL STANDARD VENTS AND DRAINS SHOWN WITH 1/2" AND 3/4" SMALL 1/2" IN. SIZE CONNECTIONS WITH 1/2" IN. SIZE PIPE, VALVES & FITTINGS.
 5. THIS P&ID CONTAINS SYSTEMS OR PORTIONS OF SYSTEMS:
 - FA-AUXILIARY BOILERS
 - FB-AUXILIARY STEAM
 - AD-CONDENSATE
 - AN-FRESH WATER PRETREATMENT
 - CA-TURBINE SEALING STEAM
 - CO-CONDENSER AIR REMOVAL
 - FW-RFP TURBINE STEAM
 6. DELETED

STEAM TRAP ASSEMBLY TABLE

STEAM TRAP	VALVE	VALVE	VALVE	VALVE	LOCATION	SYSTEM
0-ST-174	0-V272	0-V273	0-V274	0-V275	C,3	FA
0-ST-176	0-V276	0-V277	0-V278	0-V279	C,3	FA
0-ST-177	0-V279	0-V280	0-V281	0-V282	C,3	FA
0-ST-178	0-V282	0-V283	0-V284	0-V285	C,3	FA
0-ST-179	0-V285	0-V286	0-V287	0-V288	C,3	FA
0-ST-180	0-V288	0-V289	0-V290	0-V291	C,3	FA
0-ST-181	0-V291	0-V292	0-V293	0-V294	C,3	FA
0-ST-182	0-V294	0-V295	0-V296	0-V297	C,3	FA
0-ST-183	0-V297	0-V298	0-V299	0-V300	C,3	FA
0-ST-184	0-V300	0-V301	0-V302	0-V303	C,3	FA
0-ST-185	0-V303	0-V304	0-V305	0-V306	C,3	FA
0-ST-186	0-V306	0-V307	0-V308	0-V309	C,3	FA
0-ST-187	0-V309	0-V310	0-V311	0-V312	C,3	FA
0-ST-188	0-V312	0-V313	0-V314	0-V315	C,3	FA
0-ST-189	0-V315	0-V316	0-V317	0-V318	C,3	FA
0-ST-190	0-V318	0-V319	0-V320	0-V321	C,3	FA
0-ST-191	0-V321	0-V322	0-V323	0-V324	C,3	FA
0-ST-192	0-V324	0-V325	0-V326	0-V327	C,3	FA
0-ST-193	0-V327	0-V328	0-V329	0-V330	C,3	FA
0-ST-194	0-V330	0-V331	0-V332	0-V333	C,3	FA
0-ST-195	0-V333	0-V334	0-V335	0-V336	C,3	FA
0-ST-196	0-V336	0-V337	0-V338	0-V339	C,3	FA
0-ST-197	0-V339	0-V340	0-V341	0-V342	C,3	FA
0-ST-198	0-V342	0-V343	0-V344	0-V345	C,3	FA
0-ST-199	0-V345	0-V346	0-V347	0-V348	C,3	FA
0-ST-200	0-V348	0-V349	0-V350	0-V351	C,3	FA

REGETEL
SAN FRANCISCO

P&ID
AUXILIARY STEAM

APERTURE CARD
AUXILIARY BOILER & STEAM DISTRIBUTION

DATE: 05/25/53
SHEET: 4 OF 4

RIDS

8307250752

