



- NOTES
1. VALVE TO BE PROVIDED WITH A SOFT SEAT.
 2. USE EQUIPMENT LISTING NUMBERS FOR EQUIPMENT DATA.
 3. REMOVE WASTE FLANGES FOR CONTAINMENT LEAK RATE TESTING.
 4. ANNEAL TO EXTEND DOWN 7 FEET.
 5. MAKEWAKE-UP PIECE FOR TEMPORARY INSTALLATION OF THIS FLOW METER TO BE USED FOR CONTAINMENT LEAK RATE TESTING.
 6. FLOW METER TO BE PROVIDED WITH AN OVERPRESSURE PROTECTION DEVICE TO PREVENT OVERPRESSURIZATION.
 7. WASTE AND DRAINAGE BY INSTRUCTION FOR FLOW METER.
 8. USE REDUCING INSERTS.
 9. INSTRUMENT AIR REQUIRED.

DESIGN PARAMETERS

NO.	PRESSURE	TEMPERATURE	CLASS	MATERIAL
09	30 PSIG	200°F	E	SS
23	30 PSIG	125°F	E	SS
25	115 PSIG	200°F	E	SS
27	115 PSIG	125°F	E	SS
30	115 PSIG	125°F	E	SS
31	115 PSIG	125°F	E	SS
41	30 PSIG	125°F	E	SS
47	115 PSIG	125°F	E	SS

NO.	REVISIONS	DWG.	CHKD.	DATE	APPD.	DATE	CIVIL	ALSO	DEPT.	SCALE
1	REVISED									
2	REVISED									
3	REVISED									
4	REVISED									
5	REVISED									
6	REVISED									
7	REVISED									
8	REVISED									
9	REVISED									
10	REVISED									
11	REVISED									
12	REVISED									
13	REVISED									
14	REVISED									

G.R. CONDITION 2
 G.R. CONDITION 1
 DUKES POWER COMPANY
 WINDHOLE NUCLEAR STATION UNIT 2
 FLOW DIAGRAM OF
 LIQUID WASTE RECYCLE
 SYSTEM (C-2)

DESIGNED BY: DATE: 11-15-68
 DRAWN BY: DATE: 11-15-68
 CHECKED BY: DATE: 11-15-68
 APPROVED BY: DATE: 11-15-68

DWG. NO. 11

FOR
 INFORMATION
 ONLY

8903220309

PDR RIDS

