



NOTES
 1. SHLL SIDE OF STEAM GENERATOR ALSO SHOWN ON
 2D AND CP SYSTEM.
 2. STEAMWELL LOCATED WITHIN TWO FEET OF
 STEAM GENERATOR MAINTENANCE FEEDWATER
 NOZZLE.
 3. HIGH POINT VENTS FROM LOW POINT DRAIN
 ROOF BY CONNECTION FOR FLUSH AND HYDRO.
 4. A.T.O. IS A STRAIN DEVICE.
 5. 12 SECOND MAXIMUM OPERATING TIME.

LINE NO.	PRESSURE	TEMPERATURE	CLAS	MATERIAL
08	1645 PSIG	1000 F		
10	1730 PSIG	1000 F		
12	1730 PSIG	1000 F		
14	1340 PSIG	500 F		

NO.	REVISIONS	DRN	DATE	CHKD	DATE	APPR	DATE	CIVIL	ELC	MECH	INS	INSTR
1												
2												
3												
4												
5												
6												
7												
8												
9												
10												

O. A. CONDITION 1	
DUKE POWER COMPANY	
MONTECALM STATION UNIT 0	
FLUID DRAINING OF	
AUXILIARY FEEDWATER SYSTEM	
COND	
DWG. NO.	UC-2591-1.0
SCALE	
DATE	
NO.	

FOR
 INFORMATION
 ONLY

SI
 APERTURE
 CARD

8903220336

PDR RIDS

