



REV	REFERENCE DRAWING	DATE	BY
1	PROCESS FLOW DIAG. CIRC. WATER ACID INJECTION SYSTEM	11-16-76	J-240-C
2	ACID INJECTION VENDOR SIZING DIAGRAM	03-23	J-240-C
3	DATA		
4	LOGIC DIAGRAM	05-18-78	J-240-C
5	LOGIC DIAGRAM	05-18-78	J-240-C

- NOTES:
- THIS DRAWING REPLACES DRAWING M-21-0, SHEET 1.
  - ALL ITEMS IN VENDOR PACKAGE OUTLINES OR SPECIFICATIONS BY NAME TO BE APPLIED BY ACID INJECTION VENDOR. VENDOR SHALL SPECIFY COVER LISTS.
  - SULFURIC ACID TANKS, PUMPS, AND PIPING TO BE HEAVY TRUCK AND ISOLATED TO PREVENT FISSURES.
  - PH SENSOR AND CONDUCTIVITY CELL ARE LOCATED AT THE CIRCULATING WATER DOME STRUCTURE.
  - ALL VENDOR PROVIDED INFORMATION FOR LOCAL PANELS SHOULD BE ON CONTROL PANEL OCCASION.
  - THIS PAID CONTAINS STUDIES OR PORTIONS OF SYSTEMS:
    - DA - CIRCULATING WATER
    - DE - CIRCULATING WATER ACID INJECTION.

PRO APERTURE CARD

NO.	DESCRIPTION	DATE	BY
1	REVISION		
2	REVISION		
3	REVISION		
4	REVISION		
5	REVISION		

BECTEL  
 545 FRANCISCO  
 PUBLIC SERVICE ELECTRIC AND GAS COMPANY  
 HOPE CREEK GENERATING STATION  
 PAID  
 CIRCULATING WATER ACID INJECTION  
 12000 M-21-0 OF 3

RIDS

8307250780

